

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Aug

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.032	0.031	0.047	0.043	0.049	0.034	0.049
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.052	0.036	0.049	0.036	0.052
5	0.036	0.033	0.036	0.041	0.050	0.046	0.050
6	0.043	0.043	0.045	0.039	0.054	0.063	0.063
7	0.040	0.033	0.049	0.037	0.055	0.033	0.055
8	0.031	0.031	0.053	0.041	0.065	0.043	0.065
9	0.039	0.042	0.089	0.056	0.000	0.000	0.089
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.088	0.056	0.038	0.088
12	0.037	0.036	0.044	0.053	0.047	0.039	0.053
13	0.037	0.035	0.039	0.036	0.055	0.043	0.055
14	0.043	0.000	0.045	0.037	0.035	0.035	0.045
15	0.029	0.029	0.045	0.037	0.059	0.079	0.079
16	0.043	0.000	0.000	0.051	0.045	0.045	0.051
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.041	0.051	0.041	0.051
19	0.062	0.047	0.000	0.061	0.051	0.060	0.062
20	0.058	0.000	0.000	0.033	0.029	0.026	0.058
21	0.026	0.000	0.000	0.024	0.031	0.026	0.031
22	0.024	0.024	0.000	0.024	0.026	0.027	0.027
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.060	0.033	0.039	0.060
26	0.037	0.026	0.031	0.028	0.031	0.044	0.044
27	0.022	0.000	0.000	0.020	0.024	0.022	0.024
28	0.022	0.000	0.026	0.022	0.033	0.026	0.033
29	0.022	0.000	0.000	0.020	0.031	0.082	0.082
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? Yes/No All daily turbidity readings ≤ 1 NTU? Yes/No All turbidity readings < IFE² triggers Yes/No	Monthly Summary (Answer Yes or No) <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;"> CT's met everyday? (see back) Yes/No </td> <td style="width:50%;"> All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/No </td> </tr> </table>	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/No
CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/No		

Notes:	PRINTED NAME: Ronald Wanper SIGNATURE: <i>Ronald Wanper</i> PHONE #: (503) 738-5112
	DATE: 9/2/25 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-Aug

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.02	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.00	115	67.85	21.6	7.40	11	Yes	2400
4	0.59	123	123.00	21.7	7.50	11	Yes	2300
5	1.00	123	126.69	21.8	7.50	12	Yes	2300
6	1.03	115	116.15	21.5	7.50	12	Yes	2400
7	1.01	110	102.30	21.4	7.50	11	Yes	2500
8	0.93	115	104.65	21.5	7.50	11	Yes	2400
9	0.91	0	0.00	0.0	0.00	0	Yes	0
10	0.00	115	39.10	21.7	7.30	11	Yes	2400
11	0.34	115	103.50	21.9	7.50	11	Yes	2400
12	0.90	115	116.15	22.1	7.40	12	Yes	2400
13	1.01	115	101.20	22.1	7.40	11	Yes	2400
14	0.88	115	129.95	22.0	7.40	12	Yes	2400
15	1.13	115	120.75	21.9	7.40	12	Yes	2400
16	1.05	0	0.00	0.0	0.00	0	Yes	0
17	0.00	115	51.75	21.8	7.40	11	Yes	2400
18	0.45	115	104.65	21.9	7.40	11	Yes	2400
19	0.91	115	95.45	21.8	7.40	11	Yes	2400
20	0.83	115	97.75	21.6	7.60	13	Yes	2400
21	0.85	115	103.50	21.6	7.50	11	Yes	2400
22	0.90	0	0.00	0.0	0.00	0	Yes	0
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.00	115	31.05	21.4	7.40	11	Yes	2400
25	0.27	115	117.30	21.1	7.50	12	Yes	2400
26	1.02	123	136.53	21.1	7.50	12	Yes	2300
27	1.11	123	125.46	20.1	7.50	12	Yes	2300
28	1.02	123	127.92	20.5	7.50	12	Yes	2300
29	1.04	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012