

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Sep

System Name: SEASIDE

ID#: 4100799

WTP - : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.054	0.066	0.056	0.066
2	0.054	0.052	0.023	0.056	0.065	0.054	0.065
3	0.054	0.052	0.029	0.026	0.031	0.026	0.054
4	0.028	0.000	0.000	0.043	0.026	0.024	0.043
5	0.024	0.000	0.000	0.023	0.026	0.026	0.026
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.024	0.031	0.027	0.031
9	0.026	0.025	0.000	0.024	0.024	0.024	0.026
10	0.024	0.025	0.024	0.026	0.029	0.026	0.029
11	0.027	0.026	0.026	0.026	0.026	0.024	0.027
12	0.024	0.024	0.000	0.024	0.028	0.026	0.028
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.026	0.026	0.026	0.026
16	0.026	0.000	0.000	0.028	0.026	0.028	0.028
17	0.028	0.027	0.000	0.026	0.026	0.026	0.028
18	0.026	0.026	0.000	0.026	0.029	0.027	0.029
19	0.028	0.000	0.000	0.026	0.029	0.029	0.029
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.033	0.028	0.030	0.033
23	0.028	0.000	0.000	0.026	0.026	0.026	0.028
24	0.026	0.026	0.000	0.026	0.026	0.026	0.026
25	0.028	0.026	0.000	0.029	0.026	0.029	0.029
26	0.026	0.026	0.000	0.026	0.026	0.026	0.026
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.028	0.028	0.026	0.028
30	0.028	0.028	0.000	0.035	0.031	0.032	0.035
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU? ☒ Yes ☐ No

All daily turbidity readings $\leq$ 1 NTU? ☒ Yes ☐ No

All turbidity readings < IFE² triggers ☒ Yes ☐ No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) ☒ Yes ☐ No

All Cl₂ residual at entry point $\geq$ 0.2 mg/l? ☒ Yes ☐ No

Notes:

PRINTED NAME: Ronald Wanper

SIGNATURE: *Ronald Wanper*

DATE: 10/1/25

PHONE #: (503) 738-5112

T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Indiv. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-Sep

System Name: Seaside

ID#: 4100799

WTP -: A

Disinfection
Giardia Log
Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.75	123	92.25	20.0	7.30	11	Yes	2300
2	0.68	123	83.64	20.0	7.50	11	Yes	2300
3	0.80	123	98.40	20.2	7.50	11	Yes	2300
4	0.89	123	109.47	20.1	7.30	11	Yes	2300
5	1.02	123	125.46	19.9	7.50	15	Yes	2300
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.66	148	97.68	19.8	7.50	15	Yes	2000
9	0.76	148	112.48	19.9	7.50	15	Yes	2000
10	0.85	148	125.80	19.9	7.50	15	Yes	2000
11	1.03	148	152.44	19.8	7.50	15	Yes	2000
12	0.96	148	142.08	19.5	7.50	15	Yes	2000
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.76	148	112.48	19.3	7.50	15	Yes	2000
16	0.95	148	140.60	19.3	7.50	15	Yes	2000
17	1.05	148	155.40	19.5	7.50	15	Yes	2000
18	1.03	148	152.44	19.3	7.50	15	Yes	2000
19	1.00	148	148.00	18.9	7.40	15	Yes	2000
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.64	148	94.72	18.5	7.50	15	Yes	2000
23	0.81	148	119.88	18.6	7.40	15	Yes	2000
24	0.93	148	137.64	18.5	7.50	15	Yes	2000
25	0.96	148	142.08	18.3	7.50	15	Yes	2000
26	1.03	148	152.44	17.9	7.50	15	Yes	2000
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.76	148	112.48	18.1	7.50	15	Yes	2000
30	0.97	148	143.56	17.8	7.50	15	Yes	2000
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012