

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Oct

System Name:

SEASIDE

ID#: 4100799

WTP - : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.028	0.036	0.000	0.034	0.028	0.028	0.036
2	0.028	0.000	0.000	0.033	0.037	0.041	0.041
3	0.035	0.036	0.000	0.028	0.026	0.027	0.036
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.000	0.000	0.000	0.000
6	0.000	0.000	0.000	0.045	0.041	0.043	0.045
7	0.048	0.000	0.000	0.041	0.049	0.045	0.049
8	0.045	0.000	0.000	0.046	0.047	0.046	0.047
9	0.049	0.000	0.000	0.046	0.047	0.045	0.049
10	0.051	0.046	0.000	0.055	0.054	0.042	0.055
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13	0.000	0.000	0.000	0.033	0.039	0.041	0.041
14	0.043	0.000	0.000	0.040	0.039	0.036	0.043
15	0.035	0.033	0.000	0.034	0.031	0.031	0.035
16	0.029	0.034	0.000	0.031	0.035	0.033	0.035
17	0.031	0.029	0.000	0.029	0.032	0.036	0.036
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20	0.000	0.000	0.000	0.037	0.031	0.031	0.037
21	0.030	0.000	0.000	0.029	0.031	0.031	0.031
22	0.037	0.000	0.000	0.031	0.033	0.032	0.037
23	0.031	0.031	0.031	0.029	0.034	0.031	0.034
24	0.042	0.000	0.000	0.047	0.028	0.029	0.047
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27	0.000	0.000	0.000	0.031	0.029	0.030	0.031
28	0.000	0.000	0.000	0.043	0.040	0.047	0.047
29	0.050	0.000	0.000	0.032	0.028	0.028	0.050
30	0.031	0.037	0.042	0.057	0.059	0.069	0.069
31	0.000	0.000	0.000	0.028	0.030	0.031	0.031

Conventional or Direct Filtration

95% of daily turbidity readings $\leq$ 0.3 NTU?

Yes/No

All daily turbidity readings $\leq$ 1 NTU?

Yes/No

All turbidity readings < IFE² triggers

Yes/No

Notes:

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)

Yes/No

All Cl2 residual at entry point $\geq$ 0.2 mg/l?

Yes/No

PRINTED NAME: Ronald Wanner

SIGNATURE: *Ronald Wanner*

DATE: 11/3/25

PHONE #: (503) 738-5112

T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

11/25

System Name: Seaside

ID#: 4100799

WTP -: A

Disinfection
Giardia Log
Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hot Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.99	148	146.52	17.4	7.40	15	Yes	2000
2	1.01	148	149.48	17.1	7.50	15	Yes	2000
3	0.93	148	137.64	16.9	7.40	15	Yes	2000
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.00	0	0.00	0.0	0.00	0	Yes	0
6	0.76	148	112.48	16.8	7.50	15	Yes	2000
7	0.96	148	142.08	16.8	7.50	15	Yes	2000
8	0.97	148	143.56	16.7	7.50	15	Yes	2000
9	0.98	148	145.04	16.3	7.50	15	Yes	2000
10	0.94	148	139.12	16.2	7.40	15	Yes	2000
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.00	0	0.00	0.0	0.00	0	Yes	0
13	0.71	148	105.08	15.3	7.30	15	Yes	2000
14	0.95	148	140.60	14.9	7.50	22	Yes	2000
15	1.01	148	149.48	14.6	7.40	22	Yes	2000
16	1.02	148	150.96	14.1	7.40	23	Yes	2000
17	1.01	148	149.48	14.4	7.40	23	Yes	2000
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.00	0	0.00	0.0	0.00	0	Yes	0
20	1.01	148	149.48	13.9	7.50	23	Yes	2000
21	0.97	148	143.56	13.6	7.50	23	Yes	2000
22	0.98	148	145.04	13.9	7.50	23	Yes	2000
23	1.06	148	156.88	13.7	7.40	23	Yes	2000
24	0.99	148	146.52	13.8	7.40	22	Yes	2000
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.00	0	0.00	0.0	0.00	0	Yes	0
27	0.66	148	97.68	13.0	7.40	22	Yes	2000
28	0.88	148	130.24	12.9	7.40	22	Yes	2000
29	0.81	148	119.88	12.8	7.40	22	Yes	2000
30	0.93	148	137.64	12.7	7.50	22	Yes	2000
31	0.76	148	112.48	12.5	7.50	22	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012