

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Nov

System Name:		SEASIDE		ID#: 4100799		WTP - : A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.070	0.055	0.054	0.070
4	0.034	0.000	0.000	0.077	0.080	0.070	0.080
5	0.064	0.000	0.000	0.032	0.031	0.044	0.064
6	0.045	0.000	0.000	0.052	0.027	0.028	0.052
7	0.040	0.000	0.000	0.050	0.035	0.029	0.050
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.033	0.029	0.028	0.033
11	0.045	0.052	0.050	0.046	0.047	0.045	0.052
12	0.049	0.000	0.000	0.030	0.028	0.028	0.049
13	0.026	0.000	0.000	0.033	0.031	0.031	0.033
14	0.029	0.000	0.000	0.028	0.028	0.024	0.029
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.027	0.035	0.036	0.036
18	0.029	0.029	0.029	0.026	0.031	0.031	0.031
19	0.035	0.000	0.000	0.049	0.037	0.033	0.049
20	0.033	0.000	0.000	0.030	0.030	0.031	0.033
21	0.033	0.000	0.000	0.030	0.048	0.039	0.048
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.029	0.031	0.029	0.031
25	0.030	0.030	0.000	0.030	0.045	0.041	0.045
26	0.041	0.041	0.000	0.026	0.031	0.033	0.041
27	0.031	0.000	0.000	0.032	0.046	0.042	0.046
28	0.037	0.000	0.000	0.035	0.070	0.063	0.070
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? Yes/No All daily turbidity readings ≤ 1 NTU? Yes/No All turbidity readings < IFE² triggers Yes/No	Monthly Summary (Answer Yes or No) <table border="1" style="width:100%;"> <tr> <td style="width:50%;"> CT's met everyday? (see back) Yes/No </td> <td style="width:50%;"> All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/No </td> </tr> </table>	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/No
CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes/No		

Notes:	PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> PHONE #: (503) 738-5112
	DATE: 12/1/23 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = (Individ. Filter Eff. (333-061-0040(1)(e)(B&C)))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-Nov

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.68	148	100.64	12.8	7.50	22	Yes	2000
4	0.87	148	128.76	12.6	7.40	22	Yes	2000
5	0.80	148	118.40	12.6	7.50	22	Yes	2000
6	0.88	148	130.24	12.7	7.50	22	Yes	2000
7	0.89	148	131.72	12.7	7.50	22	Yes	2000
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.70	148	103.60	12.9	7.50	22	Yes	2000
11	0.93	148	137.64	12.6	7.40	22	Yes	2000
12	0.87	148	128.76	12.5	7.30	22	Yes	2000
13	0.72	148	106.56	12.7	7.40	22	Yes	2000
14	0.92	148	136.16	12.6	7.30	22	Yes	2000
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	1.03	148	152.44	12.9	7.50	23	Yes	2000
18	1.05	148	155.40	12.4	7.50	23	Yes	2000
19	0.95	148	140.60	12.0	7.40	22	Yes	2000
20	0.97	148	143.56	11.7	7.50	22	Yes	2000
21	0.94	148	139.12	11.9	7.50	22	Yes	2000
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.82	148	121.36	11.1	7.30	22	Yes	2000
25	1.03	148	152.44	10.6	7.40	23	Yes	2000
26	1.01	148	149.48	10.5	7.40	23	Yes	2000
27	0.99	148	146.52	10.6	7.50	23	Yes	2000
28	0.97	148	143.56	10.9	7.30	22	Yes	2000
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012