

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

25-Dec

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.047	0.047	0.047	0.047
2	0.047	0.050	0.069	0.058	0.070	0.068	0.070
3	0.053	0.000	0.000	0.057	0.047	0.050	0.057
4	0.049	0.000	0.000	0.045	0.067	0.063	0.067
5	0.000	0.000	0.000	0.054	0.049	0.047	0.054
6	0.000	0.000	0.000	0.000	0.000	0.000	0.000
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.038	0.041	0.041	0.041
9	0.051	0.050	0.000	0.061	0.052	0.052	0.061
10	0.000	0.000	0.000	0.052	0.061	0.052	0.061
11	0.000	0.000	0.000	0.052	0.065	0.056	0.065
12	0.054	0.061	0.000	0.053	0.065	0.066	0.066
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.062	0.058	0.068	0.068
16	0.070	0.062	0.054	0.070	0.061	0.051	0.070
17	0.000	0.000	0.000	0.062	0.052	0.057	0.062
18	0.000	0.000	0.000	0.054	0.062	0.068	0.068
19	0.052	0.063	0.000	0.065	0.057	0.049	0.065
20	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.052	0.043	0.051	0.052
23	0.071	0.062	0.000	0.061	0.051	0.047	0.071
24	0.056	0.052	0.055	0.058	0.062	0.054	0.062
25	0.054	0.062	0.000	0.058	0.063	0.063	0.063
26	0.054	0.000	0.000	0.055	0.068	0.052	0.068
27	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.061	0.052	0.054	0.061
30	0.065	0.062	0.055	0.051	0.052	0.053	0.065
31	0.045	0.046	0.000	0.043	0.045	0.042	0.046

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
Notes:		PRINTED NAME: Ronald Wanner	
		SIGNATURE: <i>Ronald Wanner</i>	DATE: 1/5/20
		PHONE #: (503) 738-5112	T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

25-Dec

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.80	148	118.40	10.7	7.50	22	Yes	2000
2	1.03	148	152.44	10.5	7.50	23	Yes	2000
3	1.02	148	150.96	10.2	7.50	23	Yes	2000
4	0.94	148	139.12	10.1	7.40	22	Yes	2000
5	0.89	148	131.72	10.3	7.30	22	Yes	2000
6	0.00	0	0.00	0.0	0.00	0	Yes	0
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.78	148	115.44	10.7	7.40	22	Yes	2000
9	0.87	148	128.76	10.8	7.30	22	Yes	2000
10	0.82	148	121.36	11.0	7.50	22	Yes	2000
11	0.73	148	108.04	11.3	7.50	22	Yes	2000
12	0.83	148	122.84	11.5	7.50	22	Yes	2000
13	0.00	0	0.00	0.0	0.00	0	Yes	0
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.47	148	69.56	11.0	7.40	22	Yes	2000
16	0.72	148	106.56	12.0	7.50	22	Yes	2000
17	0.65	148	96.20	12.2	7.40	22	Yes	2000
18	0.38	148	56.24	11.7	7.30	22	Yes	2000
19	0.76	148	112.48	11.5	7.40	22	Yes	2000
20	0.00	0	0.00	0.0	0.00	0	Yes	0
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.56	148	82.88	10.9	7.60	26	Yes	2000
23	0.83	148	122.84	10.4	7.30	22	Yes	2000
24	0.62	148	91.76	10.2	7.50	22	Yes	2000
25	0.84	165	138.60	10.0	7.40	22	Yes	1800
26	0.85	165	140.25	9.7	7.30	42	Yes	1800
27	0.00	0	0.00	0.0	0.00	0	Yes	0
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.70	148	103.60	9.1	7.30	41	Yes	2000
30	0.97	148	143.56	8.7	7.40	42	Yes	2000
31	0.94	148	139.12	8.5	7.50	42	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012