

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

26-Jan

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.062	0.052	0.000	0.060	0.043	0.057	0.062
2	0.000	0.000	0.000	0.053	0.060	0.057	0.060
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.000	0.058	0.072	0.063	0.072
6	0.076	0.056	0.066	0.071	0.067	0.060	0.076
7	0.075	0.068	0.000	0.065	0.066	0.054	0.075
8	0.000	0.000	0.000	0.068	0.062	0.064	0.068
9	0.059	0.000	0.000	0.065	0.058	0.050	0.065
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.072	0.070	0.062	0.072
13	0.070	0.068	0.056	0.074	0.072	0.058	0.074
14	0.000	0.000	0.000	0.058	0.069	0.050	0.069
15	0.047	0.000	0.000	0.065	0.068	0.049	0.068
16	0.047	0.000	0.000	0.050	0.059	0.045	0.059
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19	0.000	0.000	0.042	0.043	0.054	0.047	0.054
20	0.043	0.040	0.000	0.042	0.050	0.054	0.054
21	0.000	0.000	0.000	0.053	0.043	0.041	0.053
22	0.039	0.041	0.000	0.045	0.046	0.056	0.056
23	0.000	0.000	0.000	0.061	0.054	0.048	0.061
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.045	0.047	0.048	0.048
27	0.048	0.000	0.000	0.051	0.081	0.055	0.081
28	0.051	0.000	0.000	0.031	0.033	0.035	0.051
29	0.000	0.000	0.000	0.039	0.047	0.072	0.072
30	0.067	0.000	0.000	0.042	0.034	0.033	0.067
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Ronald Wanner
SIGNATURE: Ronald Wanner DATE: 2/2/26
PHONE #: (503) 738-5112 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

26-Jan

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.94	148	139.12	8.4	7.40	42	Yes	2000
2	0.96	148	142.08	8.6	7.20	42	Yes	2000
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.88	148	130.24	9.0	7.30	41	Yes	2000
6	1.10	148	162.80	8.8	7.30	42	Yes	2000
7	1.05	148	155.40	8.6	7.60	52	Yes	2000
8	1.03	148	152.44	8.6	7.40	42	Yes	2000
9	0.99	148	146.52	8.7	7.50	42	Yes	2000
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.59	148	87.32	9.2	7.80	42	Yes	2000
13	1.18	148	174.64	9.4	7.50	43	Yes	2000
14	1.11	148	164.28	9.6	7.50	43	Yes	2000
15	1.11	148	164.28	9.5	7.30	43	Yes	2000
16	1.10	148	162.80	9.4	7.50	43	Yes	2000
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.00	0	0.00	0.0	0.00	0	Yes	0
19	0.94	148	139.12	9.1	7.30	42	Yes	2000
20	1.10	148	162.80	8.7	7.40	43	Yes	2000
21	1.02	148	150.96	8.4	7.50	43	Yes	2000
22	1.09	148	161.32	8.1	7.30	43	Yes	2000
23	0.99	148	146.52	7.9	7.30	42	Yes	2000
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.91	148	134.68	7.1	7.30	42	Yes	2000
27	1.05	148	155.40	7.1	7.50	42	Yes	2000
28	0.88	148	130.24	7.4	7.40	41	Yes	2000
29	0.94	148	139.12	8.0	7.40	41	Yes	2000
30	1.00	148	148.00	8.3	7.40	42	Yes	2000
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012