

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

26-Mar

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.038	0.039	0.039	0.039
3	0.039	0.043	0.048	0.047	0.053	0.048	0.053
4	0.041	0.000	0.000	0.039	0.039	0.039	0.041
5	0.000	0.000	0.000	0.049	0.039	0.041	0.049
6	0.043	0.000	0.000	0.045	0.056	0.046	0.056
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.041	0.041	0.041	0.041
10	0.041	0.043	0.045	0.045	0.077	0.051	0.077
11	0.000	0.000	0.000	0.047	0.045	0.047	0.047
12	0.000	0.000	0.000	0.045	0.045	0.047	0.047
13	0.050	0.000	0.000	0.060	0.064	0.059	0.064
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.043	0.047	0.054	0.054
17	0.054	0.070	0.000	0.070	0.064	0.052	0.070
18	0.048	0.000	0.000	0.041	0.040	0.040	0.048
19	0.000	0.000	0.000	0.048	0.057	0.072	0.072
20	0.071	0.000	0.000	0.063	0.041	0.034	0.071
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.029	0.029	0.030	0.030
24	0.029	0.032	0.000	0.040	0.031	0.031	0.040
25	0.030	0.000	0.000	0.028	0.030	0.031	0.031
26	0.029	0.030	0.000	0.039	0.043	0.037	0.043
27	0.036	0.000	0.000	0.029	0.030	0.037	0.037
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.029	0.031	0.030	0.031
31	0.028	0.028	0.000	0.044	0.041	0.033	0.044

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Ronald Wanner	DATE: 4/1/26
SIGNATURE: <i>Ronald Wanner</i>	T-08898
PHONE #: (503) 738-5112	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

26-Mar

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.89	148	131.72	9.1	7.40	43	Yes	2000
3	1.04	148	153.92	9.4	7.50	43	Yes	2000
4	1.01	148	149.48	9.7	7.50	43	Yes	2000
5	1.00	148	148.00	9.8	7.50	42	Yes	2000
6	1.03	148	152.44	9.9	7.50	43	Yes	2000
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.93	148	137.64	10.4	7.30	42	Yes	2000
10	0.80	148	118.40	10.0	7.50	22	Yes	2000
11	0.94	148	139.12	9.9	7.50	42	Yes	2000
12	1.09	148	161.32	10.0	7.50	23	Yes	2000
13	1.14	148	168.72	10.1	7.50	23	Yes	2000
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.64	148	94.72	10.1	7.30	22	Yes	2000
17	0.86	148	127.28	10.4	7.70	27	Yes	2000
18	0.92	148	136.16	10.5	7.30	22	Yes	2000
19	0.94	148	139.12	10.5	7.50	22	Yes	2000
20	0.87	148	128.76	11.0	7.30	22	Yes	2000
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.89	148	131.72	10.9	7.30	22	Yes	2000
24	0.63	148	93.24	10.8	7.80	26	Yes	2000
25	1.03	148	152.44	10.7	7.40	23	Yes	2000
26	1.09	148	161.32	10.5	7.50	23	Yes	2000
27	1.06	148	156.88	10.5	7.60	23	Yes	2000
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.94	148	139.12	10.7	7.40	22	Yes	2000
31	1.16	148	171.68	10.9	7.40	23	Yes	2000

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012