

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration


County: CLATSOP

1-Jan

System Name: SEASIDE ID#: 4100799 WTP - : A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.020	0.000	0.000	0.020	0.028	0.024	0.028
2	0.022	0.022	0.000	0.000	0.000	0.000	0.022
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.044	0.026	0.024	0.044
5	0.024	0.000	0.000	0.026	0.034	0.060	0.060
6	0.000	0.000	0.000	0.034	0.026	0.024	0.034
7	0.022	0.024	0.000	0.023	0.024	0.022	0.024
8	0.020	0.000	0.000	0.020	0.030	0.022	0.030
9	0.020	0.000	0.000	0.000	0.000	0.000	0.020
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.018	0.028	0.020	0.028
12	0.018	0.000	0.000	0.018	0.018	0.024	0.024
13	0.000	0.000	0.000	0.026	0.022	0.020	0.026
14	0.027	0.000	0.000	0.024	0.020	0.022	0.027
15	0.022	0.020	0.024	0.044	0.028	0.022	0.044
16	0.020	0.020	0.000	0.000	0.000	0.000	0.020
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.026	0.028	0.020	0.028
19	0.020	0.000	0.000	0.016	0.018	0.016	0.020
20	0.000	0.000	0.000	0.020	0.022	0.020	0.022
21	0.018	0.016	0.000	0.015	0.026	0.020	0.026
22	0.020	0.018	0.000	0.018	0.022	0.020	0.022
23	0.020	0.019	0.000	0.000	0.000	0.000	0.020
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.000	0.026	0.022	0.020	0.026
26	0.018	0.018	0.000	0.018	0.018	0.018	0.018
27	0.000	0.000	0.000	0.024	0.020	0.018	0.024
28	0.018	0.018	0.000	0.030	0.022	0.020	0.030
29	0.018	0.018	0.000	0.036	0.024	0.020	0.036
30	0.020	0.018	0.000	0.000	0.000	0.000	0.020
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

<b>Conventional or Direct Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 0.3 NTU? <span style="float: right;">Yes / No</span>	CT's met everyday? (see back) <span style="float: right;">Yes / No</span>	All Cl2 residual at entry point ≥ 0.2 mg/l? <span style="float: right;">Yes / No</span>
All daily turbidity readings ≤ 1 NTU? <span style="float: right;">Yes / No</span>		
All turbidity readings < IFE <sup>2</sup> triggers <span style="float: right;">Yes / No</span>		

Notes:	PRINTED NAME: Mike Dimmick	
	SIGNATURE: 	DATE: 1 FEB 21
	PHONE #: ( 503 ) 738-5112	CERT #: 422982

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

Jan-21

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv: 0.5		
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.05	148	155.40	9.6	7.70	52	Yes	2000
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.80	148	118.40	0.5	7.60	28	Yes	2000
5	1.04	148	153.92	10.3	7.40	23	Yes	2000
6	0.98	148	145.04	10.4	7.70	27	Yes	2000
7	1.06	148	156.88	10.3	7.50	23	Yes	2000
8	1.06	148	156.88	10.3	7.50	23	Yes	2000
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.89	148	131.72	10.2	7.60	27	Yes	2000
12	1.11	148	164.28	10.6	7.50	23	Yes	2000
13	1.04	148	153.92	10.9	7.50	23	Yes	2000
14	1.00	148	148.00	10.7	7.40	22	Yes	2000
15	1.05	148	155.40	11.0	7.50	23	Yes	2000
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.87	148	128.76	10.9	7.50	22	Yes	2000
19	1.11	148	164.28	10.6	7.50	23	Yes	2000
20	1.09	148	161.32	10.2	7.50	23	Yes	2000
21	1.13	148	167.24	10.1	7.50	23	Yes	2000
22	1.13	148	167.24	10.1	7.50	23	Yes	2000
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.91	148	134.68	9.3	7.50	42	Yes	2000
26	1.11	148	164.28	8.9	7.50	43	Yes	2000
27	1.08	148	159.84	8.6	7.50	43	Yes	2000
28	1.14	148	168.72	8.4	7.50	43	Yes	2000
29	1.15	148	170.20	8.3	7.60	52	Yes	2000
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012