

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP


21-Feb

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.022	0.022	0.020	0.022
2	0.020	0.000	0.000	0.032	0.024	0.022	0.032
3	0.020	0.000	0.000	0.020	0.024	0.024	0.024
4	0.024	0.000	0.000	0.022	0.026	0.022	0.026
5	0.020	0.020	0.000	0.034	0.028	0.028	0.034
6	0.028	0.000	0.000	0.000	0.000	0.000	0.028
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.024	0.022	0.022	0.024
9	0.020	0.000	0.000	0.018	0.024	0.020	0.024
10	0.018	0.000	0.000	0.018	0.026	0.020	0.026
11	0.018	0.000	0.000	0.018	0.022	0.020	0.022
12	0.020	0.018	0.000	0.018	0.021	0.019	0.021
13	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.022	0.020	0.020	0.022
16	0.018	0.018	0.000	0.062	0.022	0.020	0.062
17	0.018	0.000	0.000	0.020	0.026	0.022	0.026
18	0.022	0.022	0.000	0.034	0.024	0.022	0.034
19	0.020	0.019	0.000	0.020	0.026	0.020	0.026
20	0.020	0.000	0.000	0.000	0.000	0.000	0.020
21	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22	0.000	0.000	0.000	0.018	0.023	0.020	0.023
23	0.022	0.020	0.000	0.018	0.018	0.022	0.022
24	0.000	0.000	0.000	0.042	0.024	0.020	0.042
25	0.020	0.020	0.000	0.024	0.028	0.022	0.028
26	0.022	0.000	0.000	0.022	0.026	0.022	0.026
27	0.025	0.000	0.000	0.000	0.000	0.000	0.025
28	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Mike Dimmick

SIGNATURE: 

DATE: _____

PHONE #: (503) 738-5112

CERT #: 423782

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

21-Feb

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	1.04	148	153.92	8.9	7.50	43	Yes	2000
3	1.13	148	167.24	8.9	7.50	43	Yes	2000
4	1.10	148	162.80	8.8	7.50	43	Yes	2000
5	1.10	148	162.80	8.9	7.50	43	Yes	2000
6	1.13	148	167.24	9.1	7.50	43	Yes	2000
7	0.00	0	0.00	0.0	0.00	0	Yes	0
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.92	148	136.16	9.5	7.60	51	Yes	2000
10	1.10	148	162.80	9.0	7.60	52	Yes	2000
11	1.10	148	162.80	9.0	7.50	43	Yes	2000
12	1.08	148	159.84	9.1	7.50	43	Yes	2000
13	1.08	148	159.84	8.5	7.50	43	Yes	2000
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.94	148	139.12	8.6	7.60	51	Yes	2000
17	1.05	148	155.40	8.7	7.50	43	Yes	2000
18	1.06	148	156.88	8.8	7.50	43	Yes	2000
19	1.08	148	159.84	9.0	7.50	43	Yes	2000
20	1.11	148	164.28	9.1	7.60	52	Yes	2000
21	0.00	0	0.00	0.0	0.00	0	Yes	0
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.91	148	134.68	9.7	7.50	42	Yes	2000
24	1.14	148	168.72	9.7	7.50	43	Yes	2000
25	1.08	148	159.84	9.6	7.60	52	Yes	2000
26	1.09	148	161.32	9.7	7.60	52	Yes	2000
27	1.06	148	156.88	9.7	7.60	52	Yes	2000
28	0.00	0	0.00	0.0	0.00	0	Yes	0
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012