

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

23-Jan

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.016	0.027	0.022	0.027
3	0.020	0.000	0.000	0.018	0.018	0.018	0.020
4	0.018	0.000	0.000	0.018	0.026	0.022	0.026
5	0.020	0.020	0.000	0.019	0.018	0.018	0.020
6	0.000	0.000	0.000	0.019	0.024	0.020	0.024
7	0.020	0.018	0.018	0.000	0.000	0.000	0.020
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.018	0.034	0.020	0.034
10	0.000	0.000	0.000	0.018	0.018	0.018	0.018
11	0.018	0.018	0.000	0.018	0.024	0.022	0.024
12	0.020	0.000	0.000	0.018	0.020	0.018	0.020
13	0.018	0.000	0.000	0.018	0.027	0.022	0.027
14	0.022	0.000	0.000	0.000	0.000	0.000	0.022
15	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16	0.000	0.000	0.000	0.020	0.026	0.022	0.026
17	0.022	0.022	0.000	0.020	0.020	0.019	0.022
18	0.018	0.000	0.000	0.019	0.024	0.022	0.024
19	0.020	0.020	0.000	0.020	0.026	0.022	0.026
20	0.020	0.000	0.000	0.024	0.018	0.018	0.024
21	0.018	0.000	0.000	0.000	0.000	0.000	0.018
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.018	0.024	0.020	0.024
24	0.020	0.019	0.000	0.018	0.018	0.018	0.020
25	0.018	0.000	0.000	0.018	0.027	0.022	0.027
26	0.020	0.019	0.000	0.018	0.020	0.018	0.020
27	0.018	0.000	0.000	0.029	0.022	0.020	0.029
28	0.020	0.018	0.000	0.000	0.000	0.000	0.020
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.018	0.034	0.022	0.034
31	0.020	0.000	0.000	0.020	0.020	0.020	0.020

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
Notes:		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> PHONE #: (503) 738-5112 DATE: 2/1/23 T-08898	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Jan

System Name:		Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv:	
								0.5	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]	
1	0.00	0	0.00	0.0	0.00	0	Yes	0	
2	0.90	148	133.20	10.4	7.50	22	Yes	2000	
3	1.00	148	148.00	10.1	7.40	22	Yes	2000	
4	1.02	148	150.96	10.0	7.60	28	Yes	2000	
5	1.07	148	158.36	9.8	7.50	43	Yes	2000	
6	1.06	148	156.88	10.0	7.30	23	Yes	2000	
7	1.37	148	202.76	10.1	7.30	23	Yes	2000	
8	0.00	0	0.00	0.0	0.00	0	Yes	0	
9	1.31	148	193.88	10.2	7.50	23	Yes	2000	
10	1.17	148	173.16	10.3	7.50	23	Yes	2000	
11	0.82	148	121.36	10.4	7.50	22	Yes	2000	
12	1.19	148	176.12	10.6	7.40	23	Yes	2000	
13	1.16	148	171.68	10.8	7.50	23	Yes	2000	
14	1.21	148	179.08	10.8	7.50	23	Yes	2000	
15	0.00	0	0.00	0.0	0.00	0	Yes	0	
16	1.01	148	149.48	11.1	7.30	23	Yes	2000	
17	1.18	148	174.64	11.0	7.50	23	Yes	2000	
18	1.12	148	165.76	11.0	7.40	22	Yes	2000	
19	1.12	148	165.76	10.6	7.40	22	Yes	2000	
20	1.10	148	162.80	10.3	7.40	23	Yes	2000	
21	1.17	148	173.16	10.4	7.40	23	Yes	2000	
22	0.00	0	0.00	0.0	0.00	0	Yes	0	
23	0.97	148	143.56	10.2	7.30	22	Yes	2000	
24	0.84	148	124.32	9.6	7.50	42	Yes	2000	
25	1.09	148	161.32	10.2	7.60	23	Yes	2000	
26	1.09	148	161.32	9.6	7.50	43	Yes	2000	
27	1.05	148	155.40	10.0	7.40	23	Yes	2000	
28	1.10	148	162.80	10.0	7.40	23	Yes	2000	
29	0.00	0	0.00	0.0	0.00	0	Yes	0	
30	0.90	148	133.20	9.3	7.30	42	Yes	2000	
31	1.01	148	149.48	8.8	7.40	43	Yes	2000	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012