

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

23-Apr

System Name: SEASIDE ID#: 4100799 WTP - : A							
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.000	0.019	0.035	0.024	0.035
4	0.022	0.021	0.020	0.018	0.032	0.022	0.032
5	0.022	0.020	0.019	0.018	0.032	0.023	0.032
6	0.021	0.020	0.019	0.018	0.028	0.023	0.028
7	0.022	0.020	0.000	0.020	0.031	0.024	0.031
8	0.022	0.020	0.000	0.000	0.000	0.000	0.022
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.020	0.032	0.026	0.032
11	0.024	0.022	0.000	0.020	0.032	0.026	0.032
12	0.020	0.000	0.000	0.021	0.034	0.026	0.034
13	0.024	0.022	0.020	0.042	0.026	0.022	0.042
14	0.022	0.000	0.000	0.020	0.032	0.024	0.032
15	0.022	0.000	0.000	0.000	0.000	0.000	0.022
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.022	0.036	0.028	0.036
18	0.025	0.024	0.024	0.022	0.034	0.027	0.034
19	0.026	0.000	0.000	0.022	0.030	0.028	0.030
20	0.024	0.023	0.000	0.022	0.034	0.028	0.034
21	0.025	0.000	0.000	0.022	0.036	0.026	0.036
22	0.024	0.000	0.000	0.000	0.000	0.000	0.024
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.020	0.034	0.024	0.034
25	0.023	0.022	0.000	0.020	0.028	0.026	0.028
26	0.022	0.022	0.000	0.020	0.029	0.024	0.029
27	0.022	0.022	0.000	0.020	0.030	0.023	0.030
28	0.022	0.020	0.000	0.022	0.032	0.022	0.032
29	0.020	0.042	0.000	0.000	0.000	0.000	0.042
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration 95% of daily turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / <input type="radio"/> No		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:		PRINTED NAME: Ronald Wanner SIGNATURE: <i>Ronald Wanner</i> DATE: 5/1/2023 PHONE #: (503) 738-5112 T-08898	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Apr

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection <i>Giardia</i> Log Inactiv: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.96	148	142.08	10.7	7.60	27	Yes	2000
4	1.22	148	180.56	10.7	7.50	23	Yes	2000
5	1.22	148	180.56	10.7	7.50	23	Yes	2000
6	1.21	148	179.08	10.9	7.50	23	Yes	2000
7	1.15	148	170.20	11.2	7.50	23	Yes	2000
8	1.19	148	176.12	11.3	7.40	23	Yes	2000
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	1.02	148	150.96	12.0	7.30	23	Yes	2000
11	1.11	148	164.28	11.8	7.50	23	Yes	2000
12	1.10	148	162.80	11.9	7.50	23	Yes	2000
13	1.14	148	168.72	12.0	7.40	23	Yes	2000
14	1.05	148	155.40	12.1	7.40	23	Yes	2000
15	0.00	0	0.00	0.0	0.00	0	Yes	0
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.93	148	137.64	12.5	7.60	27	Yes	2000
18	1.15	148	170.20	11.9	7.50	23	Yes	2000
19	1.06	148	156.88	11.6	7.40	23	Yes	2000
20	1.14	148	168.72	11.8	7.40	23	Yes	2000
21	1.11	148	164.28	11.7	7.40	23	Yes	2000
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	1.01	148	149.48	12.6	7.40	23	Yes	2000
25	1.12	148	165.76	12.8	7.40	23	Yes	2000
26	1.18	148	174.64	13.1	7.40	23	Yes	2000
27	1.15	148	170.20	13.4	7.40	23	Yes	2000
28	1.16	148	171.68	14.0	7.40	23	Yes	2000
29	1.18	223	263.14	14.2	7.40	23	Yes	1100
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012