

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

23-Jun

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.043	0.000	0.000	0.063	0.055	0.055	0.063
2	0.056	0.000	0.000	0.039	0.042	0.042	0.056
3	0.036	0.032	0.034	0.000	0.000	0.000	0.036
4	0.000	0.000	0.000	0.000	0.000	0.000	0.000
5	0.000	0.000	0.031	0.034	0.040	0.039	0.040
6	0.036	0.033	0.043	0.044	0.044	0.036	0.044
7	0.038	0.034	0.036	0.034	0.046	0.040	0.046
8	0.038	0.038	0.000	0.044	0.051	0.046	0.051
9	0.042	0.039	0.040	0.060	0.050	0.048	0.060
10	0.045	0.041	0.000	0.000	0.000	0.000	0.045
11	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12	0.000	0.000	0.000	0.048	0.057	0.048	0.057
13	0.042	0.042	0.048	0.043	0.042	0.040	0.048
14	0.046	0.046	0.048	0.044	0.054	0.042	0.054
15	0.041	0.042	0.040	0.048	0.046	0.036	0.048
16	0.035	0.035	0.036	0.047	0.040	0.038	0.047
17	0.036	0.036	0.036	0.042	0.039	0.038	0.042
18	0.038	0.049	0.042	0.000	0.000	0.000	0.049
19	0.000	0.000	0.050	0.036	0.037	0.034	0.050
20	0.000	0.000	0.000	0.034	0.044	0.037	0.044
21	0.036	0.034	0.000	0.035	0.052	0.041	0.052
22	0.040	0.043	0.000	0.036	0.043	0.038	0.043
23	0.036	0.000	0.000	0.039	0.056	0.043	0.056
24	0.041	0.044	0.042	0.000	0.000	0.000	0.044
25	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26	0.000	0.000	0.000	0.053	0.046	0.041	0.053
27	0.041	0.040	0.038	0.042	0.037	0.036	0.042
28	0.034	0.034	0.000	0.032	0.036	0.034	0.036
29	0.032	0.000	0.000	0.034	0.046	0.036	0.046
30	0.032	0.000	0.000	0.032	0.039	0.036	0.039
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Ronald Wanner	DATE: 7/3/23
SIGNATURE: <i>Ronald Wanner</i>	
PHONE #: (503) 738-5112	T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Jun

System Name: Seaside ID#: 4100799 WTP -: A Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.97	132	128.04	17.6	7.40	15	Yes	2200
2	1.03	132	135.96	17.7	7.50	15	Yes	2200
3	1.10	132	145.20	18.0	7.40	15	Yes	2200
4	0.00	0	0.00	0.0	0.00	0	Yes	0
5	0.79	123	97.17	18.0	7.50	15	Yes	2300
6	1.16	115	133.40	18.1	7.40	15	Yes	2400
7	1.19	115	136.85	18.2	7.50	15	Yes	2400
8	1.12	115	128.80	18.3	7.50	15	Yes	2400
9	1.14	115	131.10	18.4	7.50	15	Yes	2400
10	1.19	148	176.12	18.2	7.40	15	Yes	2000
11	0.00	0	0.00	0.0	0.00	0	Yes	0
12	0.60	115	69.00	18.1	7.50	15	Yes	2400
13	1.09	115	125.35	18.5	7.40	15	Yes	2400
14	0.99	115	113.85	18.4	7.50	15	Yes	2400
15	1.07	123	131.61	18.3	7.40	15	Yes	2300
16	1.12	123	137.76	18.4	7.50	15	Yes	2300
17	1.05	123	129.15	18.6	7.50	15	Yes	2300
18	1.09	123	134.07	18.6	7.50	15	Yes	2300
19	0.97	123	119.31	18.0	7.50	15	Yes	2300
20	1.04	123	127.92	18.1	7.50	15	Yes	2300
21	1.05	123	129.15	18.1	7.50	15	Yes	2300
22	1.00	123	123.00	18.1	7.50	15	Yes	2300
23	0.93	123	114.39	18.4	7.50	15	Yes	2300
24	1.02	123	125.46	18.5	7.60	19	Yes	2300
25	0.00	0	0.00	0.0	0.00	0	Yes	0
26	0.69	123	84.87	18.6	7.50	15	Yes	2300
27	0.97	123	119.31	18.9	7.70	18	Yes	2300
28	1.06	123	130.38	19.1	7.60	19	Yes	2300
29	0.86	123	105.78	19.2	7.50	15	Yes	2300
30	0.91	123	111.93	19.4	7.50	15	Yes	2300
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012