

OHA - Drinking Water Program - Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: CLATSOP

23-Jul

System Name: SEASIDE		ID#: 4100799		WTP - : A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.000	0.000	0.000	0.000
2	0.000	0.000	0.000	0.000	0.000	0.000	0.000
3	0.000	0.000	0.036	0.037	0.036	0.036	0.037
4	0.034	0.036	0.036	0.056	0.040	0.038	0.056
5	0.037	0.036	0.040	0.047	0.048	0.040	0.048
6	0.036	0.039	0.040	0.047	0.049	0.046	0.049
7	0.044	0.046	0.000	0.050	0.046	0.054	0.054
8	0.040	0.043	0.057	0.050	0.000	0.000	0.057
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.045	0.044	0.048	0.045	0.048
11	0.042	0.044	0.053	0.044	0.049	0.031	0.053
12	0.044	0.048	0.048	0.048	0.066	0.044	0.066
13	0.045	0.045	0.000	0.052	0.057	0.044	0.057
14	0.046	0.000	0.000	0.054	0.056	0.046	0.056
15	0.046	0.055	0.084	0.068	0.000	0.000	0.084
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.076	0.067	0.061	0.076
18	0.067	0.066	0.070	0.078	0.081	0.068	0.081
19	0.076	0.067	0.084	0.070	0.067	0.070	0.084
20	0.070	0.076	0.072	0.072	0.059	0.059	0.076
21	0.063	0.060	0.000	0.063	0.075	0.054	0.075
22	0.050	0.051	0.060	0.000	0.000	0.000	0.060
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.058	0.060	0.054	0.060
25	0.056	0.060	0.058	0.054	0.063	0.064	0.064
26	0.048	0.052	0.052	0.048	0.058	0.062	0.062
27	0.058	0.056	0.058	0.052	0.056	0.056	0.058
28	0.052	0.056	0.052	0.056	0.060	0.052	0.060
29	0.052	0.000	0.000	0.000	0.000	0.000	0.052
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.050	0.060	0.052	0.060

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings \leq 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:

PRINTED NAME: Ronald Wanner
 SIGNATURE: *Ronald Wanner* DATE: 8/1/2023
 PHONE #: (503) 738-5112 T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Jul

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactive: 0.5		
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.00	0	0.00	0.0	0.00	0	Yes	0
3	0.56	123	68.88	19.7	7.60	17	Yes	2300
4	1.12	123	137.76	20.2	7.50	12	Yes	2300
5	1.08	123	132.84	20.4	7.50	12	Yes	2300
6	1.07	123	131.61	20.6	7.40	12	Yes	2300
7	1.03	123	126.69	20.6	7.40	12	Yes	2300
8	1.12	123	137.76	20.6	7.40	12	Yes	2300
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.35	123	43.05	20.4	7.40	11	Yes	2300
11	1.03	123	126.69	20.7	7.50	12	Yes	2300
12	1.01	123	124.23	20.9	7.50	12	Yes	2300
13	0.92	123	113.16	21.0	7.40	12	Yes	2300
14	0.98	123	120.54	21.2	7.50	11	Yes	2300
15	1.04	123	127.92	21.3	7.40	12	Yes	2300
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.45	115	51.75	21.3	7.30	11	Yes	2400
18	1.15	115	132.25	21.6	7.40	12	Yes	2400
19	1.13	115	129.95	21.6	7.50	12	Yes	2400
20	1.07	123	131.61	21.6	7.50	12	Yes	2300
21	0.79	123	97.17	21.6	7.40	11	Yes	2300
22	0.90	123	110.70	21.8	7.40	11	Yes	2300
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.21	123	25.83	21.7	7.40	11	Yes	2300
25	1.23	123	151.29	21.7	7.50	12	Yes	2300
26	1.11	123	136.53	21.8	7.40	12	Yes	2300
27	1.06	123	130.38	21.8	7.40	12	Yes	2300
28	0.95	123	116.85	21.8	7.40	11	Yes	2300
29	1.09	123	134.07	21.9	7.40	12	Yes	2300
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.70	123	86.10	21.9	7.50	11	Yes	2300

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012