

OHA - Drinking Water Program -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: CLATSOP

23-Oct

System Name: SEASIDE		ID#: 4100799			WTP - : A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.058	0.064	0.061	0.064
2	0.000	0.000	0.000	0.054	0.062	0.068	0.068
3	0.068	0.000	0.000	0.070	0.045	0.054	0.070
4	0.052	0.000	0.000	0.055	0.053	0.052	0.055
5	0.050	0.000	0.000	0.056	0.047	0.046	0.056
6	0.044	0.000	0.000	0.000	0.000	0.000	0.044
7	0.000	0.000	0.000	0.000	0.000	0.000	0.000
8	0.000	0.000	0.000	0.000	0.000	0.000	0.000
9	0.000	0.000	0.000	0.046	0.052	0.048	0.052
10	0.046	0.045	0.000	0.047	0.042	0.042	0.047
11	0.000	0.000	0.000	0.052	0.062	0.056	0.062
12	0.000	0.000	0.000	0.044	0.040	0.044	0.044
13	0.042	0.000	0.000	0.042	0.056	0.044	0.056
14	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15	0.000	0.000	0.000	0.077	0.040	0.036	0.077
16	0.000	0.000	0.000	0.038	0.052	0.041	0.052
17	0.040	0.039	0.000	0.037	0.039	0.040	0.040
18	0.000	0.000	0.000	0.038	0.042	0.036	0.042
19	0.000	0.000	0.000	0.035	0.038	0.034	0.038
20	0.000	0.000	0.000	0.032	0.040	0.036	0.040
21	0.034	0.036	0.000	0.000	0.000	0.000	0.036
22	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23	0.000	0.000	0.000	0.032	0.038	0.035	0.038
24	0.034	0.034	0.035	0.033	0.038	0.035	0.038
25	0.000	0.000	0.000	0.034	0.034	0.034	0.034
26	0.024	0.000	0.000	0.034	0.033	0.032	0.034
27	0.032	0.032	0.000	0.031	0.042	0.037	0.042
28	0.036	0.035	0.000	0.000	0.000	0.000	0.036
29	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30	0.000	0.000	0.000	0.034	0.034	0.030	0.034
31	0.030	0.030	0.000	0.030	0.028	0.026	0.030

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		

Notes:

PRINTED NAME: Ronald Wanner  
SIGNATURE: *Ronald Wanner*  
PHONE #: ( 503 ) 738-5112  
DATE: 11/1/22  
T-08898

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Oct

System Name: Seaside		ID#: 4100799		WTP -: A		Disinfection Giardia Log Inactiv:		0.5
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.00	0	0.00	0.0	0.00	0	Yes	0
2	0.67	123	82.41	19.8	7.50	15	Yes	2300
3	0.84	123	103.32	19.8	7.40	15	Yes	2300
4	0.87	123	107.01	19.0	7.50	15	Yes	2300
5	0.88	123	108.24	16.9	7.50	15	Yes	2300
6	0.90	132	118.80	16.4	0.90	15	Yes	2200
7	1.09	132	143.88	16.6	7.40	15	Yes	2200
8	0.00	0	0.00	0.0	0.00	0	Yes	0
9	0.75	132	99.00	16.8	7.60	18	Yes	2200
10	0.80	132	105.60	16.5	7.50	15	Yes	2200
11	0.94	123	115.62	16.2	7.40	15	Yes	2200
12	0.86	148	127.28	16.0	7.50	15	Yes	2000
13	0.97	132	128.04	15.9	7.40	15	Yes	2200
14	0.00	0	0.00	0.0	0.00	0	Yes	0
15	0.76	132	100.32	15.5	7.40	15	Yes	2200
16	0.75	132	99.00	15.5	7.50	15	Yes	2200
17	0.81	148	119.88	15.4	7.40	15	Yes	2000
18	0.64	148	94.72	15.3	7.40	15	Yes	2000
19	0.71	148	105.08	15.3	7.50	15	Yes	2000
20	0.65	148	96.20	15.6	7.50	15	Yes	2000
21	0.91	148	134.68	15.6	7.50	15	Yes	2000
22	0.00	0	0.00	0.0	0.00	0	Yes	0
23	0.68	132	89.76	15.6	7.40	15	Yes	2200
24	0.92	132	121.44	15.3	7.50	15	Yes	2200
25	0.82	148	121.36	14.6	7.50	22	Yes	2000
26	0.75	148	111.00	14.0	7.30	22	Yes	2000
27	0.85	148	125.80	13.4	7.60	27	Yes	2000
28	0.97	148	143.56	13.4	7.50	22	Yes	2000
29	0.00	0	0.00	0.0	0.00	0	Yes	0
30	0.64	132	84.48	12.6	7.50	22	Yes	2200
31	0.93	148	137.64	12.3	7.50	22	Yes	2000

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012