

OHA - Drinking Water Program -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: CLATSOP

23-Dec

System Name: SEASIDE ID#: 4100799 WTP -: A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.000	0.000	0.000	0.024	0.039	0.026	0.039
2	0.024	0.000	0.000	0.000	0.000	0.000	0.024
3	0.000	0.000	0.000	0.000	0.000	0.000	0.000
4	0.000	0.000	0.000	0.024	0.033	0.026	0.033
5	0.000	0.000	0.026	0.024	0.025	0.024	0.026
6	0.024	0.024	0.024	0.026	0.043	0.027	0.043
7	0.026	0.000	0.000	0.024	0.024	0.022	0.026
8	0.000	0.000	0.000	0.025	0.036	0.026	0.036
9	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11	0.000	0.000	0.000	0.025	0.033	0.027	0.033
12	0.026	0.028	0.029	0.039	0.044	0.029	0.044
13	0.030	0.000	0.000	0.030	0.035	0.030	0.035
14	0.026	0.000	0.000	0.025	0.026	0.043	0.043
15	0.044	0.000	0.000	0.046	0.029	0.026	0.046
16	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18	0.000	0.000	0.000	0.022	0.034	0.026	0.034
19	0.024	0.024	0.000	0.022	0.023	0.022	0.024
20	0.028	0.000	0.000	0.022	0.029	0.025	0.029
21	0.024	0.023	0.000	0.022	0.022	0.000	0.024
22	0.000	0.000	0.000	0.022	0.034	0.026	0.034
23	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25	0.000	0.000	0.022	0.024	0.034	0.026	0.034
26	0.024	0.024	0.024	0.023	0.022	0.022	0.024
27	0.000	0.000	0.000	0.022	0.028	0.024	0.028
28	0.024	0.024	0.000	0.022	0.022	0.022	0.024
29	0.022	0.000	0.000	0.022	0.028	0.024	0.028
30	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Conventional or Direct Filtration

95% of daily turbidity readings \leq 0.3 NTU? Yes / No
 All daily turbidity readings \leq 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No
 All Cl2 residual at entry point \geq 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Ronald Wanner

SIGNATURE: *Ronald Wanner*

DATE: 1/3/24

PHONE #: (503) 738-5112

T-08898

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Eff. (333-061-0040(1)(e)(B&C))

OHA – Drinking Water Program – Surface Water Quality Data Form

DATE

23-Dec

System Name: Seaside ID#: 4100799 WTP -: A Disinfection Giardia Log Inactiv: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.93	148	137.64	8.4	7.50	42	Yes	2000
2	1.08	148	159.84	8.6	7.40	43	Yes	2000
3	0.00	0	0.00	0.0	0.00	0	Yes	0
4	0.90	148	133.20	9.6	7.40	42	Yes	2000
5	1.03	140	144.20	10.6	8.00	23	Yes	2100
6	1.11	140	155.40	10.5	7.50	23	Yes	2100
7	1.04	148	153.92	10.5	7.50	23	Yes	2000
8	0.99	148	146.52	10.3	7.50	22	Yes	2000
9	0.00	0	0.00	0.0	0.00	0	Yes	0
10	0.00	0	0.00	0.0	0.00	0	Yes	0
11	0.86	148	127.28	10.3	7.50	22	Yes	2000
12	1.07	148	158.36	10.2	7.50	23	Yes	2000
13	1.03	148	152.44	10.0	7.50	43	Yes	2000
14	1.05	148	155.40	10.0	7.40	23	Yes	2000
15	1.00	148	148.00	10.0	7.50	22	Yes	2000
16	0.00	0	0.00	0.0	0.00	0	Yes	0
17	0.00	0	0.00	0.0	0.00	0	Yes	0
18	0.91	148	134.68	9.6	7.50	42	Yes	2000
19	1.11	148	164.28	9.7	7.40	43	Yes	2000
20	1.09	148	161.32	9.7	7.30	43	Yes	2000
21	1.11	148	164.28	9.8	7.50	43	Yes	2000
22	1.04	148	153.92	9.9	7.40	43	Yes	2000
23	0.00	0	0.00	0.0	0.00	0	Yes	0
24	0.00	0	0.00	0.0	0.00	0	Yes	0
25	0.94	148	139.12	9.4	7.40	43	Yes	2000
26	1.17	148	173.16	9.6	7.40	43	Yes	2000
27	1.02	148	150.96	9.6	7.40	43	Yes	2000
28	1.08	148	159.84	9.9	7.50	43	Yes	2000
29	1.08	148	159.84	10.2	7.40	23	Yes	2000
30	0.00	0	0.00	0.0	0.00	0	Yes	0
31	0.00	0	0.00	0.0	0.00	0	Yes	0

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Revised February 2012