

OHA - Drinking Water Program - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Clatsop  
 Month/Year: Aug-23  
 WTP: TP - A

System Name: Arch Cape Water District ID#: 41 00802

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	0.03	0.03	0.03	0.02	0.02	0.02	0.12
2	0.02	PO	PO	PO	PO	PO	0.04
3	PO	PO	PO	PO	0.02	0.02	0.19
4	0.02	0.03	0.02	0.03	0.02	0.03	0.27
5	0.03	0.03	PO	PO	PO	PO	0.03
6	PO	PO	PO	PO	PO	0.02	0.13
7	0.03	0.03	0.03	0.03	0.03	0.03	0.19
8	0.03	0.03	0.03	0.03	0.03	0.03	0.14
9	0.03	0.03	PO	PO	PO	PO	0.19
10	PO	PO	PO	0.03	0.03	0.03	0.14
11	0.03	0.03	0.02	0.03	0.03	0.03	0.10
12	0.03	PO	PO	PO	PO	PO	0.03
13	PO	PO	PO	0.02	0.03	0.03	0.16
14	0.03	0.03	0.03	0.03	0.03	0.03	0.75
15	0.03	0.04	PO	PO	PO	PO	0.16
16	PO	PO	PO	0.03	0.03	0.03	0.17
17	0.03	0.02	0.03	0.03	0.03	0.03	0.26
18	0.04	0.02	0.02	0.03	PO	PO	1.22
19	PO	PO	PO	PO	0.04	0.03	0.08
20	0.03	0.03	0.03	0.03	0.03	0.03	0.68
21	0.03	0.03	PO	PO	PO	PO	0.05
22	PO	PO	PO	PO	0.03	0.03	0.20
23	0.03	0.02	0.03	0.02	0.03	0.02	0.21
24	0.02	0.02	PO	PO	PO	PO	0.54
25	PO	PO	PO	PO	0.03	0.03	0.06
26	0.03	0.03	0.03	0.02	0.02	0.02	0.17
27	0.03	0.03	PO	PO	PO	PO	0.45
28	PO	PO	PO	0.02	0.04	0.03	0.15
29	0.03	0.03	0.03	0.03	0.03	0.03	1.26
30	PO	PO	PO	PO	PO	PO	PO
31	PO	PO	PO	PO	PO	PO	PO

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup>	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: Matthew R. Gardner	
		SIGNATURE: <i>M.R. Gardner</i>	
		DATE: 9-1-23	
		PHONE #: 503) 436 2790	CERT #: T-09382

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

County: Clatsop

WTP: A

System Name: Arch Cape Water District ID#: 41 00802 Month/Year: Aug-23

Disinfection *Giardia* Log Inactiv: 0.50

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.82	243	199.4	17.7	7.52	13.5	Yes	92
2	0.76	212	161.4	17.7	7.54	13.5		105
3	0.74	264	195.6	17.7	7.43	12.9		81
4	0.71	205	145.3	18.2	7.51	12.9		108
5	0.71	242	171.9	18.2	7.41	12.4		93
6	0.69	450	310.7	18.1	7.42	12.5		48
7	0.69	277	191.2	18.4	7.43	12.3		77
8	0.72	244	175.9	18.5	7.44	12.3		91
9	0.71	317	225.4	18.4	7.40	12.2		72
10	0.69	262	180.7	18.4	7.43	12.3		82
11	0.71	232	164.4	18.4	7.40	12.2		96
12	0.71	246	174.5	18.4	7.40	12.2		93
13	0.68	209	141.8	18.4	7.39	12.1		101
14	0.72	252	181.7	18.9	7.37	11.7		87
15	0.71	268	190.3	18.8	7.45	12.1		85
16	0.7	248	173.7	18.9	7.41	11.8		86
17	0.75	235	176.0	19.3	7.38	11.4		93
18	0.74	271	200.8	19.0	7.33	11.4		85
19	0.7	226	158.0	18.6	7.35	11.8		97
20	0.7	225	157.8	18.6	7.32	11.6		98
21	0.69	294	202.8	18.2	7.39	12.3		78
22	0.65	287	186.7	18.1	7.45	12.6		75
23	0.66	227	149.7	18.2	7.33	12.0		98
24	0.66	302	199.1	17.8	7.29	12.1		76
25	0.63	326	205.7	17.9	7.32	12.1		66
26	0.65	231	150.1	18.3	7.35	11.9		96
27	0.71	230	163.4	18.0	7.30	12.0		99
28	0.65	222	144.6	18.0	7.37	12.3		95
29	0.7	343	240.2	17.9	7.34	12.3		65
30	0.69	316	218.4	17.7	7.31	12.3		72
31	0.67	288	193.1	17.7	7.32	12.3		75

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.

Enter data in green shaded cells.

Date	Total Contact Time (min)	Lowest Reservoir Level (ft)	Volume/ft of depth (gal)	Baffling Factor (%)	Effective Reservoir Volume (gal)	Peak Hour Demand (gpm)	Tank Contact Time (min)	Pipe Diameter (in)	Pipe Length (ft)	Pipe Volume (gal) (baffling = 1)	Pipe Contact Time (min)
1	243	26.4	18,381	0.0375	18,197	92	188	8	1,600	4,176	45
2	212	26.3	18,381	0.0375	18,128	105	173	8	1,600	4,176	40
3	264	25	18,381	0.0375	17,232	81	213	8	1,600	4,176	52
4	205	26	18,381	0.0375	17,921	108	166	8	1,600	4,176	39
5	242	26.6	18,381	0.0375	18,335	93	197	8	1,600	4,176	45
6	450	25.3	18,381	0.0375	17,439	48	363	8	1,600	4,176	87
7	277	24.9	18,381	0.0375	17,163	77	223	8	1,600	4,176	54
8	244	26.2	18,381	0.0375	18,059	91	198	8	1,600	4,176	46
9	317	27.1	18,381	0.0375	18,680	72	259	8	1,600	4,176	58
10	262	25.1	18,381	0.0375	17,301	82	211	8	1,600	4,176	51
11	232	26.2	18,381	0.0375	18,059	96	188	8	1,600	4,176	43
12	246	27.1	18,381	0.0375	18,680	93	201	8	1,600	4,176	45
13	209	24.5	18,381	0.0375	16,888	101	167	8	1,600	4,176	41
14	252	25.8	18,381	0.0375	17,784	87	204	8	1,600	4,176	48
15	268	27	18,381	0.0375	18,611	85	219	8	1,600	4,176	49
16	248	24.9	18,381	0.0375	17,163	86	200	8	1,600	4,176	49
17	235	25.6	18,381	0.0375	17,646	93	190	8	1,600	4,176	45
18	271	27.4	18,381	0.0375	18,886	85	222	8	1,600	4,176	49
19	226	25.7	18,381	0.0375	17,715	97	183	8	1,600	4,176	43
20	225	26	18,381	0.0375	17,921	98	183	8	1,600	4,176	43
21	294	27.2	18,381	0.0375	18,749	78	240	8	1,600	4,176	54
22	287	25.2	18,381	0.0375	17,370	75	232	8	1,600	4,176	56
23	227	26.2	18,381	0.0375	18,059	98	184	8	1,600	4,176	43
24	302	27.2	18,381	0.0375	18,749	76	247	8	1,600	4,176	55
25	326	25.2	18,381	0.0375	17,370	66	263	8	1,600	4,176	63
26	231	26.1	18,381	0.0375	17,990	96	187	8	1,600	4,176	43
27	230	27	18,381	0.0375	18,611	99	188	8	1,600	4,176	42
28	222	24.6	18,381	0.0375	16,956	95	178	8	1,600	4,176	44
29	343	26.3	18,381	0.0375	18,128	65	279	8	1,600	4,176	64
30	316	27	18,381	0.0375	18,611	72	258	8	1,600	4,176	58
31	288	25.3	18,381	0.0375	17,439	75	233	8	1,600	4,176	56