


**OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Jackson**  
**Conventional or Direct Filtration**

System Name: COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP:-WTP-A Month/Year: 5/21

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	↓	↓	↓	1.089	↓	↓	1.089
2	↓	↓	↓	1.098	↓	↓	1.098
3	↓	↓	↓	1.089	↓	↓	1.089
4	↓	↓	↓	1.081	↓	↓	1.081
5	↓	↓	↓	1.088	↓	↓	1.088
6	↓	↓	↓	OFF	↓	↓	OFF
7	↓	↓	↓	OFF	↓	↓	↓
8	↓	↓	↓	1.088	↓	↓	1.088
9	↓	↓	↓	1.088	↓	↓	1.088
10	↓	↓	↓	1.089	↓	↓	1.089
11	↓	↓	↓	1.099	↓	↓	1.099
12	↓	↓	↓	1.093	↓	↓	1.093
13	↓	↓	↓	OFF	↓	↓	OFF
14	↓	↓	↓	OFF	↓	↓	OFF
15	↓	↓	↓	1.093	↓	↓	1.093
16	↓	↓	↓	1.089	↓	↓	1.089
17	↓	↓	↓	1.091	↓	↓	1.091
18	↓	↓	↓	1.091	↓	↓	1.091
19	↓	↓	↓	1.089	↓	↓	1.089
20	↓	↓	↓	OFF	↓	↓	OFF
21	↓	↓	↓	↓	↓	↓	↓
22	↓	↓	↓	↓	↓	↓	↓
23	↓	↓	↓	↓	↓	↓	↓
24	↓	↓	↓	↓	↓	↓	↓
25	↓	↓	↓	1.089	↓	↓	1.089
26	↓	↓	↓	1.093	↓	↓	1.093
27	↓	↓	↓	1.091	↓	↓	1.091
28	↓	↓	↓	↓	↓	↓	↓
29	↓	↓	↓	↓	↓	↓	↓
30	↓	↓	↓	↓	↓	↓	↓
31	↓	↓	↓	↓	↓	↓	↓

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CI's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No			
Notes: PLANT RUNS 3 TO 4 HRS	PRINTED NAME: AL EATINGER	SIGNATURE: 	DATE: 6/4/21
	PHONE #: (541) 1973-9200		CERT #: 6097

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.  
<sup>2</sup> IFE = Individ. Filter Eff. (CAR 333-061-0040(1)(e)(B&C))

# OHA - Drinking Water Program – Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP: WTP-A Month/Year: 5/21

Required Log  
Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	G X T	[° C]		Use tables	Yes / No	[GPM]
11/11 AM	.30	150	54.0	11	7.8	17	(900)	32
2/1	.30	↓	↓	↓	7.8	↓	↓	↓
3/1	.30		↓		7.8	↓		↓
4/1	.30		↓		7.8	↓		↓
5/1	.30		↓		7.8	↓		↓
6/1	.30		↓		7.8	↓		↓
7/1	.30		↓	↓	7.8	↓		↓
8/1	—		—	OFF	—	→		—
9/1	—		—	OFF	—	→		—
10/1	.32		57.4	11	7.8	17		32
11/1	.32		57.6	11	7.9	↓		32
12/1	.34		61.2	12	8.1	↓		34
13/1	.34		61.2	12	7.9	↓		34
14/1	.34		61.2	12	7.7	↓		34
15/1	—		—	OFF	—	→		—
16/1	—		—	OFF	—	→		—
17/1	.30		54.0	13	7.8	17		34
18/1	.30		↓	↓	7.9	↓		↓
19/1	.30		↓	↓	7.9	↓		↓
20/1	.30		↓	↓	7.8	↓		↓
21/1	.30		↓	↓	7.9	↓		↓
22/1	OFF		OFF	OFF	—	→		—
23/1	↓		—	↓	—	→		—
24/1	↓		—	↓	—	→		—
25/1	.35		63.0	14	7.8	17		30
26/1	.35		63.0	14	7.9	17		32
27/1	.35		63.0	14	7.8	17		30
28/1	OFF		OFF	OFF	—	→		—
29/1	↓		↓	↓	—	→		—
30/1	↓		↓	↓	—	→		—
31/1	↓	↓	↓	↓	—	→	↓	—

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.