

OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Jackson
Conventional or Direct Filtration

System Name: COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP:-WTP-A Month/Year: 7/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	↓	↓	↓	.087	↓	↓	.087
2	↓	↓	↓	.087	↓	↓	.087
3	↓	↓	↓	OFF	↓	↓	OFF
4	↓	↓	↓	↓	↓	↓	↓
5	↓	↓	↓	.089	↓	↓	.089
6	↓	↓	↓	.083	↓	↓	.083
7	↓	↓	↓	.089	↓	↓	.089
8	↓	↓	↓	.088	↓	↓	.088
9	↓	↓	↓	.088	↓	↓	.088
10	↓	↓	↓	OFF	↓	↓	OFF
11	↓	↓	↓	↓	↓	↓	↓
12	↓	↓	↓	.087	↓	↓	.087
13	↓	↓	↓	.087	↓	↓	.087
14	↓	↓	↓	OFF	↓	↓	OFF
15	↓	↓	↓	.069	↓	↓	.069
16	↓	↓	↓	.069	↓	↓	.069
17	↓	↓	↓	OFF	↓	↓	OFF
18	↓	↓	↓	↓	↓	↓	↓
19	↓	↓	↓	↓	↓	↓	↓
20	↓	↓	↓	.089	↓	↓	.089
21	↓	↓	↓	.089	↓	↓	.089
22	↓	↓	↓	.069	↓	↓	.069
23	↓	↓	↓	.072	↓	↓	.072
24	↓	↓	↓	OFF	↓	↓	OFF
25	↓	↓	↓	↓	↓	↓	↓
26	↓	↓	↓	.072	↓	↓	.072
27	↓	↓	↓	.070	↓	↓	.070
28	↓	↓	↓	.070	↓	↓	.070
29	↓	↓	↓	.069	↓	↓	.069
30	↓	↓	↓	.070	↓	↓	.070
31	↓	↓	↓	OFF	↓	↓	OFF

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CI's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes <input type="radio"/> No			
Notes: PLANT RUNS 3 TO 4 HRS	PRINTED NAME: AL EATINGER		
	SIGNATURE: <i>[Signature]</i>	DATE: 8/1/21	
	PHONE #: 1541 1973-9200	CERT #: 6097	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP-: WTP-A Month/Year: 7/2021

Required Log
Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/11 AM	.34	150	61.2	14	8.1	17	(Yes)	36
2/1	.34	✓	61.2	14	8.0	17	✓	30
3/1	—		—	—	—	—		—
4/1	—		—	—	—	—		—
5/1	.34		61.2	14	8.1	17		36
6/1	.34		61.2	↓	8.2	↓		↓
7/1	.25		49.0	↓	8.1	↓		↓
8/1	.21		37.8	↓	↓	↓		↓
9/1	.32		57.6	↓	↓	↓		↓
10/1	—		—	—	—	—		—
11/1	—		—	—	—	—		—
12/1	.35		63.0	15	8.1	17		32
13/1	.35		63.0	15	8.1	17		32
14/1	—		—	—	—	—		—
15/1	.32		57.6	14	8.0	17		32
16/1	.31		55.8	14	8.1	17		32
17/1	—		—	—	—	—		+
18/1	—		—	—	—	—		+
19/1	—		—	—	—	—		+
20/1	.30		54.0	14	8.1	17		32
21/1	.30		54.0	↓	8.0	↓		↓
22/1	.31		55.8	↓	8.1	↓		↓
23/1	.33		59.4	↓	8.1	↓		↓
24/1	—		—	—	—	—		—
25/1	—		—	—	—	—		—
26/1	.40		73.8	14	8.0	17		34
27/1	.40		73.8	↓	8.1	↓		↓
28/1	.40		73.8	↓	8.0	↓		↓
29/1	.40		73.8	↓	8.0	↓		↓
30/1	.40		73.8	↓	8.0	↓		↓
31/1	.40	✓	73.8	↓	8.0	↓	✓	↓

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.