

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Jackson
 Conventional or Direct Filtration

System Name: COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP:-WTP-A Month/Year: 8/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	↓	↓	↓	.068	↓	↓	.068
2	↓	↓	↓	↓	↓	↓	↓
3	↓	↓	↓	.068	↓	↓	.068
4	↓	↓	↓	.069	↓	↓	.069
5	↓	↓	↓	.068	↓	↓	.068
6	↓	↓	↓	.069	↓	↓	.069
7	↓	↓	↓	OFF	↓	↓	OFF
8	↓	↓	↓	↓	↓	↓	↓
9	↓	↓	↓	↓	↓	↓	↓
10	↓	↓	↓	.098	↓	↓	.098
11	↓	↓	↓	.075	↓	↓	.075
12	↓	↓	↓	.069	↓	↓	.069
13	↓	↓	↓	.085	↓	↓	.085
14	↓	↓	↓	OFF	↓	↓	OFF
15	↓	↓	↓	↓	↓	↓	↓
16	↓	↓	↓	.069	↓	↓	.069
17	↓	↓	↓	.071	↓	↓	.071
18	↓	↓	↓	.071	↓	↓	.071
19	↓	↓	↓	.071	↓	↓	.071
20	↓	↓	↓	.071	↓	↓	.071
21	↓	↓	↓	OFF	↓	↓	OFF
22	↓	↓	↓	↓	↓	↓	↓
23	↓	↓	↓	↓	↓	↓	↓
24	↓	↓	↓	.099	↓	↓	.099
25	↓	↓	↓	.099	↓	↓	.099
26	↓	↓	↓	.075	↓	↓	.075
27	↓	↓	↓	.089	↓	↓	.089
28	↓	↓	↓	OFF	↓	↓	OFF
29	↓	↓	↓	↓	↓	↓	↓
30	↓	↓	↓	.089	↓	↓	.089
31	↓	↓	↓	.072	↓	↓	.072

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Cl ₂ 's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Notes: PLANT RUNS 3 TO 4 hrs		
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No ²	PRINTED NAME: AL EATINGER	DATE: 8/2/21	
	SIGNATURE: <i>[Signature]</i>	PHONE #: (541) 973-9200	
	PHONE #: (541) 973-9200	CERT #: 6097	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
²IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP: WTP-A Month/Year: 8/2021

Required Log
Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	G X T	[° C]		Use tables	Yes / No	[GPM]
1/11 AM	↓	150	↓	↓	↓	↓	500	↓
2/1	↓	↓	↓	↓	↓	↓	↓	↓
3/1	.30		54.0	16	8.1	17		34
4/1	.32		57.6	16	8.2	↓		↓
5/1	.30		54.0	16	8.1	↓		↓
6/1	.32		57.6	16	8.0	↓		↓
7/1	T		T	OFF	T	T		T
8/1	↓		↓	↓	↓	↓		↓
9/1	↓		↓	↓	↓	↓		↓
10/1	.30		54.0	16	8.3	17		34
11/1	.30		54.0	↓	8.1	↓		↓
12/1	.32		57.6	↓	8.1	↓		↓
13/1	.32		57.6	↓	8.1	↓		↓
14/1	T		T	OFF	T	T		T
15/1	↓		↓	↓	↓	↓		↓
16/1	.40		72.0	17	8.1	17		36
17/1	.40		72.0	↓	8.0	↓		↓
18/1	.38		68.4	↓	8.0	↓		↓
19/1	.31		55.8	↓	8.0	↓		↓
20/1	.31		55.8	↓	8.0	↓		↓
21/1	T		T	OFF	T	T		T
22/1	↓		↓	↓	↓	↓		↓
23/1	↓		↓	↓	↓	↓		↓
24/1	.31		55.8	17	8.2	17		31
25/1	.30		54.0	16	8.2	↓		30
26/1	.30		54.0	16	8.2	↓		30
27/1	.32		57.6	16	8.1	↓		32
28/1	✓		—	OFF	T	T		T
29/1	✓		—	OFF	↓	↓		↓
30/1	.30		54.0	15	8.1	17		30
31/1	.30	↓	54.0	15	8.0	17	↓	32

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.