

**OHA - Drinking Water Program - Turbidity Monitoring Report Form** County: Jackson  
 Conventional or Direct Filtration

System Name: COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP:-WTP-A Month/Year: Sept / 2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	↓	↓	↓	.088	↓	↓	.088
2	↓	↓	↓	.087	↓	↓	.087
3	↓	↓	↓	.091	↓	↓	.091
4	↓	↓	↓	OFF	↓	↓	OFF
5	↓	↓	↓	↓	↓	↓	↓
6	↓	↓	↓	.098	↓	↓	.098
7	↓	↓	↓	.070	↓	↓	.070
8	↓	↓	↓	.072	↓	↓	.072
9	↓	↓	↓	.072	↓	↓	.072
10	↓	↓	↓	.073	↓	↓	.073
11	↓	↓	↓	OFF	↓	↓	OFF
12	↓	↓	↓	↓	↓	↓	↓
13	↓	↓	↓	.080	↓	↓	.080
14	↓	↓	↓	.072	↓	↓	.072
15	↓	↓	↓	.072	↓	↓	.072
16	↓	↓	↓	.080	↓	↓	.080
17	↓	↓	↓	.091	↓	↓	.091
18	↓	↓	↓	OFF	↓	↓	OFF
19	↓	↓	↓	↓	↓	↓	↓
20	↓	↓	↓	.091	↓	↓	.091
21	↓	↓	↓	.089	↓	↓	.089
22	↓	↓	↓	.077	↓	↓	.077
23	↓	↓	↓	.070	↓	↓	.070
24	↓	↓	↓	.090	↓	↓	.090
25	↓	↓	↓	OFF	↓	↓	OFF
26	↓	↓	↓	↓	↓	↓	↓
27	↓	↓	↓	.098	↓	↓	.098
28	↓	↓	↓	.076	↓	↓	.076
29	↓	↓	↓	OFF	↓	↓	OFF
30	↓	↓	↓	↓	↓	↓	↓
31	↓	↓	↓	↓	↓	↓	↓

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CI's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <sup>2</sup>			
Notes: <u>Plant Run's 3 to 4 hrs</u>	PRINTED NAME: <u>AL EATINGER</u>		
	SIGNATURE: <u>[Signature]</u>	DATE: <u>10/3/21</u>	
	PHONE #: <u>1541 1973-9200</u>	CERT #: <u>6097</u>	

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.  
<sup>2</sup>IFE = Individ. Filter Effl. (CAR 333-051-0040(1)(e)(B&C))

## OHA - Drinking Water Program – Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP-: WTP-A Month/Year: 9/2021

Required Log  
Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
11/11 AM	.30	150	54.0	14	8.0	17	950	34
21	.30	↓	↓	↓	8.1	↓	↓	↓
31	.30		↓	↓	8.0	↓		↓
41	—		—	—	—	—		—
51	—		—	—	—	—		—
61	.30		54.0	15	8.0	17		34
71	.32		57.6	15	8.1	↓		↓
81	.32		57.6	14	8.0	↓		↓
91	.30		54.0	↓	8.1	↓		↓
101	.30		54.0	↓	8.0	↓		↓
111	—		—	—	—	—		—
121	—		—	—	—	—		—
131	.34		61.2	14	8.1	17		34
141	.34		61.2	↓	8.1	↓		↓
151	.34		61.2	↓	8.0	↓		↓
161	.34		61.2	↓	8.1	↓		↓
171	.32		57.6	↓	8.1	↓		↓
181	—		—	—	—	—		—
191	—		—	—	—	—		—
201	.30		54.0	13	8.0	17		34
211	.33		59.4	↓	8.2	↓		↓
221	.35		63.0	↓	8.0	↓		↓
231	.35		63.0	↓	8.1	↓		↓
241	.35		63.0	↓	8.0	↓		↓
251	—		—	—	—	—		—
261	—		—	—	—	—		—
271	.30		54.0	13	8.0	17		34
281	.32		57.6	↓	8.1	↓		↓
291	off		↓	↓	↓	↓		↓
301	↓		↓	↓	↓	↓		↓
311	↓	↓	↓				↓	↓

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.