

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Jackson
Conventional or Direct Filtration**

System Name: COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP:-WTP-A Month/Year: 2/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	✓	✓	✓		✓	✓	
2	✓	✓	✓		✓	✓	
3	✓	✓	✓		✓	✓	
4	✓	✓	✓		✓	✓	
5	✓	✓	✓		✓	✓	
6	✓	✓	✓		✓	✓	
7	✓	✓	✓		✓	✓	
8	✓	✓	✓		✓	✓	
9	✓	✓	✓		✓	✓	
10	✓	✓	✓		✓	✓	
11	✓	✓	✓		✓	✓	
12	✓	✓	✓		✓	✓	
13	✓	✓	✓		✓	✓	
14	✓	✓	✓		✓	✓	
15	✓	✓	✓		✓	✓	
16	✓	✓	✓		✓	✓	
17	✓	✓	✓		✓	✓	
18	✓	✓	✓		✓	✓	
19	✓	✓	✓		✓	✓	
20	✓	✓	✓		✓	✓	
21	✓	✓	✓		✓	✓	
22	✓	✓	✓		✓	✓	
23	✓	✓	✓		✓	✓	
24	✓	✓	✓		✓	✓	
25	✓	✓	✓		✓	✓	
26	✓	✓	✓		✓	✓	
27	✓	✓	✓		✓	✓	
28	✓	✓	✓		✓	✓	
29	✓	✓	✓		✓	✓	
30	✓	✓	✓		✓	✓	
31	✓	✓	✓		✓	✓	

DOWN WELL

Conventional or Direct Filtration 95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes / No ²		Monthly Summary (Answer Yes or No) Cl ₂ 's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
Notes: PLANT RUN'S 3 TO 4 HRS		PRINTED NAME: AL EATINGER SIGNATURE: <i>[Signature]</i> DATE: 2/20/22 PHONE #: 541 1973-9200 CERT #: 6097	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
²IFE = Individ. Filter Eff. (CAR 333-051-0040(1)(e)(B&C))