

**OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Jackson**  
**Conventional or Direct Filtration**

**System Name: COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP:-WTP-A Month/Year: 8/2022**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	↓	↓	↓	.069	↓	↓	.069
2	↓	↓	↓	.054	↓	↓	.054
3	↓	↓	↓	—	↓	↓	—
4	↓	↓	↓	.059	↓	↓	.059
5	↓	↓	↓	.060	↓	↓	.060
6	↓	↓	↓	—	↓	↓	—
7	↓	↓	↓	—	↓	↓	—
8	↓	↓	↓	.060	↓	↓	.060
9	↓	↓	↓	.055	↓	↓	.055
10	↓	↓	↓	.069	↓	↓	.069
11	↓	↓	↓	—	↓	↓	—
12	↓	↓	↓	—	↓	↓	—
13	↓	↓	↓	.098	↓	↓	.098
14	↓	↓	↓	—	↓	↓	—
15	↓	↓	↓	.098	↓	↓	.098
16	↓	↓	↓	.069	↓	↓	.069
17	↓	↓	↓	.059	↓	↓	.059
18	↓	↓	↓	.061	↓	↓	.061
19	↓	↓	↓	.069	↓	↓	.069
20	↓	↓	↓	—	↓	↓	—
21	↓	↓	↓	—	↓	↓	—
22	↓	↓	↓	.069	↓	↓	.069
23	↓	↓	↓	.095	↓	↓	.095
24	↓	↓	↓	.072	↓	↓	.072
25	↓	↓	↓	.069	↓	↓	.069
26	↓	↓	↓	.054	↓	↓	.054
27	↓	↓	↓	—	↓	↓	—
28	↓	↓	↓	—	↓	↓	—
29	↓	↓	↓	.069	↓	↓	.069
30	↓	↓	↓	.067	↓	↓	.067
31	↓	↓	↓	.072	↓	↓	.072

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes <input type="radio"/> No <sup>2</sup>			
Notes: PLANT RUNS 3 TO 4 HRS	PRINTED NAME: AL EATINGER		
	SIGNATURE: <i>[Signature]</i>	DATE: 9/8/22	
	PHONE #: 1541 1973-9200	CERT #: 6097	

<sup>1</sup>Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.  
<sup>2</sup>IFE = Individ. Filter Eff. (CAR 333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP: WTP-A Month/Year: 8/1/22 / 8/31/22

Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1/ 11:45 AM	30	180	54	14	8.4	20	(50)	30
2/ ✓	30	✓	54	16	8.4	20	✓	30
3/	off		-	-	-	-		30
4/	30		54	16	8.3	20		off
5/	30		54	16	8.2	20		30
6/	off		-	-	-	-		30
7/	off		-	-	-	-		off
8/	34		61.2	16	8.4	20		off
9/	34		61.2	17	8.3	↓		30
10/	34		↓1.2	17	8.4	↓		30
11/	off		-	-	-	-		30
12/	off		-	-	-	-		off
13/	37		66.6	17	8.3	20		off
14/	off		-	-	-	-		30
15/	34		61.2	17	8.4	20		off
16/	34		61.2	↓	8.4	↓		30
17/	34		61.2	↓	8.5	↓		32
18/	34		61.2	↓	8.3	↓		32
19/	34		61.2	↓	8.4	↓		32
20/	off		-	-	-	-		33
21/	off		-	-	-	-		off
22/	34		61.2	17	8.3	20		off
23/	34		↓	↓	8.4	↓		30
24/	34		↓	↓	8.5	↓		30
25/	34		↓	↓	8.4	↓		30
26/	34		↓	↓	8.5	↓		30
27/	off		-	-	-	-		30
28/	off		-	-	-	-		off
29/	34		61.2	18	8.4	20		off
30/	34		↓	18	8.4	↓		30
31/ ✓	34	✓	↓	18	8.4	↓	✓	30

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.