


**OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Jackson  
Conventional or Direct Filtration**

**System Name: COUNTRY VIEW MH ESTATES ID #: OR4100806 WTP-WTP-A Month/Year: 12/2022**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	✓	✓	✓		✓	✓	
2	✓	✓	✓		✓	✓	
3	✓	✓	✓		✓	✓	
4	✓	✓	✓		✓	✓	
5	✓	✓	✓		✓	✓	
6	✓	✓	✓		✓	✓	
7	✓	✓	✓		✓	✓	
8	✓	✓	✓		✓	✓	
9	✓	✓	✓		✓	✓	
10	✓	✓	✓		✓	✓	
11	✓	✓	✓		✓	✓	
12	✓	✓	✓		✓	✓	
13	✓	✓	✓		✓	✓	
14	✓	✓	✓		✓	✓	
15	✓	✓	✓		✓	✓	
16	✓	✓	✓		✓	✓	
17	✓	✓	✓		✓	✓	
18	✓	✓	✓		✓	✓	
19	✓	✓	✓		✓	✓	
20	✓	✓	✓		✓	✓	
21	✓	✓	✓		✓	✓	
22	✓	✓	✓		✓	✓	
23	✓	✓	✓		✓	✓	
24	✓	✓	✓		✓	✓	
25	✓	✓	✓		✓	✓	
26	✓	✓	✓		✓	✓	
27	✓	✓	✓		✓	✓	
28	✓	✓	✓		✓	✓	
29	✓	✓	✓		✓	✓	
30	✓	✓	✓		✓	✓	
31	✓	✓	✓		✓	✓	

ON WHEELS

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes <input type="radio"/> No			
Notes: PLANT RUNS 3 TO 4 hrs		PRINTED NAME: AL EATINGER	DATE: 1/3/23
		SIGNATURE: 	CERT #: 6097
		PHONE #: (541) 973-9200	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (CAR 333-081-0040(1)(e)(B&C))