

**OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Jackson
Conventional or Direct Filtration**

System Name: COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP:-WTP-A Month/Year: 8/23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	↓	↓	↓	.145	↓	↓	.145
2	↓	↓	↓	.145	↓	↓	.145
3	↓	↓	↓	.165	↓	↓	.165
4	↓	↓	↓	.165	↓	↓	.165
5	↓	↓	↓	Wells	↓	↓	Wells
6	↓	↓	↓	"	↓	↓	"
7	↓	↓	↓	.185	↓	↓	.185
8	↓	↓	↓	.175	↓	↓	.175
9	↓	↓	↓	.175	↓	↓	.175
10	↓	↓	↓	.165	↓	↓	.165
11	↓	↓	↓	Wells	↓	↓	Wells
12	↓	↓	↓	"	↓	↓	"
13	↓	↓	↓	"	↓	↓	"
14	↓	↓	↓	.167	↓	↓	.167
15	↓	↓	↓	.164	↓	↓	.164
16	↓	↓	↓	Wells	↓	↓	Wells
17	↓	↓	↓	.174	↓	↓	.174
18	↓	↓	↓	.174	↓	↓	.174
19	↓	↓	↓	Wells	↓	↓	Wells
20	↓	↓	↓	"	↓	↓	"
21	↓	↓	↓	.195	↓	↓	.195
22	↓	↓	↓	.175	↓	↓	.175
23	↓	↓	↓	.175	↓	↓	.175
24	↓	↓	↓	.175	↓	↓	.175
25	↓	↓	↓	Wells	↓	↓	Wells
26	↓	↓	↓	"	↓	↓	"
27	↓	↓	↓	"	↓	↓	"
28	↓	↓	↓	.149	↓	↓	.149
29	↓	↓	↓	.149	↓	↓	.149
30	↓	↓	↓	.147	↓	↓	.147
31	↓	↓	↓	.140	↓	↓	.140

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Notes: PLANT RUNS 3 TO 4 HRS		PRINTED NAME: AL EATINGER	
		SIGNATURE: <i>[Signature]</i>	DATE: 9/7/23
		PHONE #: 1541 1973-9200	CERT #: 6097

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
²IFE = Individ. Filter Eff. (OAR 333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP: WTP-A Month/Year: 8/23

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1/ 11:21 AM	.30	180	54.0	15	7.8	17	(30)	34
2/ ✓	.30	✓	54.0	↓	7.8	↓	✓	↓
3/	.30		54.0	↓	7.9	↓		↓
4/	.30		54.0	↓	7.9	↓		↓
5/	—		—	off	off	—		—
6/	—		—	off	off	—		—
7/	.30		54.0	16	8.1	17		34
8/	.30		54.0	↓	8.1	↓		↓
9/	.30		54.0	↓	7.9	↓		↓
10/	.30		54.0	↓	7.9	↓		↓
11/	—		—	off	off	—		—
12/	—		—	off	off	—		—
13/	—		—	off	off	—		—
14/	.32		57.6	16	7.8	17		36
15/	.30		54.0	16	7.9	17		36
16/	—		—	off	off	—		—
17/	.30		54.0	16	8.2	17		36
18/	.39		70.2	16	8.1	17		36
19/	—		—	off	off	—		—
20/	—		—	off	off	—		—
21/	.45		81.0	16	8.1	17		36
22/	.40		72.0	16	8.2	↓		↓
23/	.37		66.6	16	8.3	↓		↓
24/	.32		57.6	16	8.1	↓		34
25/	—		—	off	off	—		—
26/	—		—	off	off	—		—
27/	—		—	off	off	—		—
28/	.30		54.0	16	8.1	17		34
29/	.30		54.0	16	8.0	↓		34
30/	.30		54.0	16	8.1	↓		34
31/ ✓	.30	✓	54.0	16	8.1	↓	✓	34

² If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.