

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Jackson
Conventional or Direct Filtration**

System Name: COUNTRY VIEW MH ESTATES ID #: OR4100008 WTP-WTP-A Month/Year: 9/2023

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	↓	↓	↓	.153	↓	↓	.153
2	↓	↓	↓	-	↓	↓	-
3	↓	↓	↓	-	↓	↓	-
4	↓	↓	↓	-	↓	↓	-
5	↓	↓	↓	.155	↓	↓	.155
6	↓	↓	↓	.168	↓	↓	.168
7	↓	↓	↓	.155	↓	↓	.155
8	↓	↓	↓	.165	↓	↓	.165
9	↓	↓	↓	-	↓	↓	-
10	↓	↓	↓	-	↓	↓	-
11	↓	↓	↓	.165	↓	↓	.165
12	↓	↓	↓	.186	↓	↓	.186
13	↓	↓	↓	.153	↓	↓	.153
14	↓	↓	↓	.169	↓	↓	.169
15	↓	↓	↓	.153	↓	↓	.153
16	↓	↓	↓	-	↓	↓	-
17	↓	↓	↓	-	↓	↓	-
18	↓	↓	↓	-	↓	↓	-
19	↓	↓	↓	.160	↓	↓	.160
20	↓	↓	↓	.155	↓	↓	.155
21	↓	↓	↓	.150	↓	↓	.150
22	↓	↓	↓	.152	↓	↓	.152
23	↓	↓	↓	-	↓	↓	-
24	↓	↓	↓	-	↓	↓	-
25	↓	↓	↓	.165	↓	↓	.165
26	↓	↓	↓	.165	↓	↓	.165
27	↓	↓	↓	.150	↓	↓	.150
28	↓	↓	↓	.150	↓	↓	.150
29	↓	↓	↓	-	↓	↓	-
30	↓	↓	↓	-	↓	↓	-
31	↓	↓	↓	-	↓	↓	-

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes <input type="radio"/> No			
Notes: PLANT RUNS 3 TO 4 HRS		PRINTED NAME: AL EATINGER	
		SIGNATURE: <i>[Signature]</i>	DATE: 10/2/23
		PHONE #: 1541 1973-9200	CERT #: 6097

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indiv. Filtr. Eff. (OAR 333-081-0040(1)(a)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4106806 WTP - WTP-A Month/Year: 9/2023

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1/ 11:15 AM	.50	180	90.0	16	8.1	17	(30)	34
2/	OFF	✓	-	-	-	-	✓	-
3/	↓	-	-	-	-	-	-	-
4/	↓	-	-	-	-	-	-	-
5/	.37	-	66.6	16	8.0	17	-	-
6/	.30	-	54.0	14	8.1	↓	-	34
7/	.30	-	54.0	16	8.0	↓	-	↓
8/	.30	-	54.0	16	8.2	✓	-	↓
9/	OFF	-	-	-	-	-	-	-
10/	↓	-	-	-	-	-	-	-
11/	.31	-	55.8	15	8.1	17	-	-
12/	.20	-	54.0	↓	8.1	↓	-	34
13/	.30	-	54.0	↓	8.1	↓	-	↓
14/	.30	-	54.0	↓	8.2	↓	-	↓
15/	.30	-	54.0	↓	8.1	↓	-	↓
16/	OFF	-	-	-	-	-	-	↓
17/	↓	-	-	-	-	-	-	-
18/	↓	-	-	-	-	-	-	-
19/	.33	-	59.4	15	8.1	17	-	-
20/	.30	-	54.0	↓	8.2	↓	-	34
21/	.35	-	63.0	↓	8.2	↓	-	↓
22/	.35	-	63.0	↓	8.2	↓	-	↓
23/	OFF	-	-	-	-	-	-	↓
24/	↓	-	-	-	-	-	-	-
25/	.33	-	59.4	15	8.2	17	-	-
26/	.30	-	54.0	↓	8.3	↓	-	34
27/	.33	-	59.4	↓	8.1	↓	-	↓
28/	.30	-	54.0	↓	8.1	↓	-	↓
29/	OFF	-	-	-	-	-	-	↓
30/	OFF	-	-	-	-	-	-	-
31/	✓	✓	-	-	-	-	✓	-

² If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.