

OHA - Drinking Water Services – Turbidity Monitoring Report
Conventional or Direct Filtration

County:

Name: COUNTRY VIEW M.H.E.

ID #41: 00808

WTP: A

Month/Year:

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	.13	OFF	OFF	.13
2				OFF			—
3				—			—
4				—			
5				.13			.13
6				.12			.12
7				.11			.11
8				.14			.14
9				OFF			—
10				—			—
11				.25			.25
12				.15			.15
13				.12			.12
14				.13			.13
15				.12			.12
16				OFF			—
17				OFF			—
18				.13			.13
19				.24			.24
20				.24			.24
21				.17			.17
22				.22			.22
23				OFF			—
24				—			—
25				—			—
26				.19			.19
27				.14			.14
28				.13			.13
29				.15			.15
30				OFF			OFF
31	↓	↓	↓	—	↓	↓	—

Conventional or Direct Filtration Monthly Summary 95% of the 4-hour turbidity readings ≤ 0.3 NTU? <u>Yes</u> / No All the 4-hour turbidity readings ≤ 1 NTU? <u>Yes</u> / No All turbidity readings < IFE ² triggers? <u>Yes</u> / No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <u>Yes</u> / No All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <u>Yes</u> / No	
Notes: <u>PLANT RUNS 3 TO 4 HRS</u>		PRINTED NAME: <u>AL EATINGER</u> SIGNATURE: <u>[Signature]</u> DATE: <u>9/3/25</u> PHONE #: <u>(541) 973-9200</u> CERT #: <u>6097</u>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Eff. (OAR 333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form - Giardia Inactivation

Name:

ID #41: 00808 WTP-:

Month/Year:

Log Requirement
(Circle One): 0.5 1.0

8/2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 / NAM	.30	180	54.0	16	8.2	20	YES	34
2 /	—	—	—	—	—	—	—	—
3 /	—	—	—	—	—	—	—	—
4 /	—	—	—	—	—	—	—	—
5 /	.26	—	46.8	17	8.1	20	—	34
6 /	.20	—	36.0	—	8.1	—	—	34
7 /	.30	—	54.0	—	8.1	—	—	34
8 /	.37	—	66.6	—	8.2	—	—	34
9 /	—	—	—	—	—	—	—	—
10 /	—	—	—	—	—	—	—	—
11 /	.38	—	68.4	17	8.2	20	—	34
12 /	.30	—	54.0	—	8.3	—	—	—
13 /	.35	—	63.0	—	8.1	—	—	—
14 /	.30	—	54.0	—	8.2	—	—	—
15 /	.30	—	54.0	—	8.2	—	—	—
16 /	—	—	—	—	—	—	—	—
17 /	—	—	—	—	—	—	—	—
18 /	.34	—	61.2	17	8.3	20	—	34
19 /	.40	—	72.0	—	8.3	—	—	—
20 /	.40	—	72.0	—	8.2	—	—	—
21 /	.35	—	63.0	—	8.2	—	—	—
22 /	.39	—	70.2	—	8.2	—	—	—
23 /	—	—	—	—	—	—	—	—
24 /	—	—	—	—	—	—	—	—
25 /	—	—	—	—	—	—	—	34
26 /	.32	—	57.6	17	8.1	20	—	—
27 /	.32	—	57.6	—	8.2	—	—	—
28 /	.30	—	54.0	—	8.2	—	—	—
29 /	.30	—	54.0	—	8.2	—	—	—
30 /	—	—	—	—	—	—	—	—
31 / ✓	—	—	—	—	—	—	—	—

³ If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWS within 24 hours

Revised November 2022

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-comv-direct.pdf

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR

97293-0350

PAGE 2 of 2