

OHA - Drinking Water Program -- Turbidity Monitoring Report Form County: Jackson
Conventional or Direct Filtration

System Name: COUNTRY VIEW MH ESTATES **ID #:** OR4100808 **WTP-:**WTP-A **Month/Year:** 9/2022

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	↓	↓	↓	.064	↓	↓	.064
2	↓	↓	↓	.067	↓	↓	.067
3	↓	↓	↓	-	↓	↓	-
4	↓	↓	↓	-	↓	↓	-
5	↓	↓	↓	.068	↓	↓	.068
6	↓	↓	↓	.060	↓	↓	.060
7	↓	↓	↓	.065	↓	↓	.065
8	↓	↓	↓	.070	↓	↓	.070
9	↓	↓	↓	.070	↓	↓	.070
10	↓	↓	↓	-	↓	↓	-
11	↓	↓	↓	-	↓	↓	-
12	↓	↓	↓	.084	↓	↓	.084
13	↓	↓	↓	.071	↓	↓	.071
14	↓	↓	↓	.089	↓	↓	.089
15	↓	↓	↓	.069	↓	↓	.069
16	↓	↓	↓	.065	↓	↓	.065
17	↓	↓	↓	-	↓	↓	-
18	↓	↓	↓	-	↓	↓	-
19	↓	↓	↓	.065	↓	↓	.065
20	↓	↓	↓	.065	↓	↓	.065
21	↓	↓	↓	OFF	↓	↓	OFF
22	↓	↓	↓	↓	↓	↓	↓
23	↓	↓	↓	↓	↓	↓	↓
24	↓	↓	↓	↓	↓	↓	↓
25	↓	↓	↓	↓	↓	↓	↓
26	↓	↓	↓	↓	↓	↓	↓
27	↓	↓	↓	↓	↓	↓	↓
28	↓	↓	↓	↓	↓	↓	↓
29	↓	↓	↓	.087	↓	↓	.087
30	↓	↓	↓	.079	↓	↓	.079
31	↓	↓	↓	-	↓	↓	-

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
All turbidity readings < IFE ² triggers? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No ²			
Notes: PLANT RUN'S 3 TO 4 hrs	PRINTED NAME: AL EATINGER		DATE: 10/3/22
	SIGNATURE: <i>[Signature]</i>		CERT #: 6097
	PHONE #: (541) 973-9200		

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
²IFE = Individ. Filter Eff. (OAR 333-081-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP: WTP-A Month/Year: 9/2022

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT Use tables	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1/ 11:14 AM	.32	180	57.6	18	8.3	20	(Yes)	34
2/ ✓	.30	✓	54.0	18	8.4	20	✓	34
3/	—	—	—	—	—	—	—	—
4/	—	—	—	—	—	—	—	—
5/	.30	—	54.0	18	8.4	20	—	—
6/	.30	—	54.0	17	8.4	—	—	34
7/	.30	—	54.0	17	8.4	—	—	↓
8/	.32	—	57.6	17	8.3	—	—	↓
9/	.30	—	54.0	17	8.3	—	—	↓
10/	—	—	—	—	—	✓	—	34
11/	—	—	—	—	—	—	—	—
12/	.30	—	54.0	15	8.4	20	—	—
13/	.30	—	↓	↓	8.4	—	—	34
14/	.30	—	↓	↓	8.4	—	—	↓
15/	.30	—	↓	↓	8.3	—	—	↓
16/	.32	—	57.6	↓	8.4	↓	—	↓
17/	—	—	—	—	—	—	—	—
18/	—	—	—	—	—	—	—	—
19/	.30	—	54.0	15	8.4	20	—	—
20/	.30	—	54.0	15	8.4	20	—	34
21/	OFF	—	OFF	OFF	OFF	OFF	—	34
22/	—	—	—	—	—	—	—	OFF
23/	—	—	—	—	—	—	—	—
24/	—	—	—	—	—	—	—	—
25/	—	—	—	—	—	—	—	—
26/	—	—	—	—	—	—	—	—
27/	—	—	—	—	—	—	—	—
28/	—	—	—	—	—	—	—	—
29/	.30	—	54.0	15	8.4	20	—	↓
30/	.30	—	54.0	15	8.3	20	—	34
31/ ✓	—	—	—	—	—	—	—	34

² If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.