

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Jackson  
Conventional or Direct Filtration**

**System Name: COUNTRY VIEW MH ESTATES ID #: OR4100806 WTP: WTP-A Month/Year: 6/23**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1	↓	↓	↓	OFF	↓	↓	OFF
2	↓	↓	↓	↓	↓	↓	↓
3	↓	↓	↓	↓	↓	↓	↓
4	↓	↓	↓	↓	↓	↓	↓
5	↓	↓	↓	↓	↓	↓	↓
6	↓	↓	↓	↓	↓	↓	↓
7	↓	↓	↓	↓	↓	↓	↓
8	↓	↓	↓	↓	↓	↓	↓
9	↓	↓	↓	.128	↓	↓	.128
10	↓	↓	↓	↓	↓	↓	↓
11	↓	↓	↓	↓	↓	↓	↓
12	↓	↓	↓	.192	↓	↓	.192
13	↓	↓	↓	.165	↓	↓	.165
14	↓	↓	↓	.164	↓	↓	.164
15	↓	↓	↓	.162	↓	↓	.162
16	↓	↓	↓	.154	↓	↓	.154
17	↓	↓	↓	↓	↓	↓	↓
18	↓	↓	↓	↓	↓	↓	↓
19	↓	↓	↓	.165	↓	↓	.165
20	↓	↓	↓	.145	↓	↓	.145
21	↓	↓	↓	.142	↓	↓	.142
22	↓	↓	↓	.141	↓	↓	.141
23	↓	↓	↓	.142	↓	↓	.142
24	↓	↓	↓	↓	↓	↓	↓
25	↓	↓	↓	↓	↓	↓	↓
26	↓	↓	↓	.151	↓	↓	.151
27	↓	↓	↓	.146	↓	↓	.146
28	↓	↓	↓	.135	↓	↓	.135
29	↓	↓	↓	.125	↓	↓	.125
30	↓	↓	↓	.188	↓	↓	.188
31	↓	↓	↓	↓	↓	↓	↓

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No			
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes <input type="radio"/> No			
<b>Notes:</b> PLANT RUN'S 3 TO 4 HRS		PRINTED NAME: <b>AL EATINGER</b>	
		SIGNATURE: <i>[Signature]</i>	DATE: 7/10/23
		PHONE #: 1541 1973-9200	CERT #: 6097

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Individ. Filter Eff. (OAR 333-081-0040(1)(a)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

COUNTRY VIEW MH ESTATES ID #: OR4100808 WTP: WTP-A Month/Year: 6/23

Required Log  
Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT GXT	Temp [°C]	pH	Required CT Use tables	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1/11 AM	OFF	180	OFF	OFF	OFF	OFF	(0/0)	OFF
2/								
3/								
4/								
5/								
6/								
7/								
8/								
9/	.30		.51	14	8.8	14		36
10/	OFF			14	8.8	14		36
11/	OFF							
12/	.37		66.6	14	8.8	14		
13/	.35		63.0	14	8.8			36
14/	.28		50.4		8.7			36
15/	.45		81.0		8.6			36
16/	.45		81.0		8.7			36
17/								36
18/								
19/	.48		86.4	14	8.8	14		36
20/	.54		97.2		8.6			
21/	.33		59.4		8.6			
22/	.33		59.4		8.7			
23/	.33		59.4		8.7			
24/								
25/								
26/	.40		72.0	15	8.2	14		36
27/	.40		72.0		8.3			
28/	.40		72.0		8.4			
29/	.40		72.0		8.4			
30/	.45		81.0		7.9			
31/								

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.