

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: YAMHILL

Conventional or Direct Filtration

Month/Year: Aug 22

System Name:	SHERIDAN, CITY OF			ID#:OR 410081			WTP:	WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	OFF	OFF	.12	.09	.09	OFF	.12	
2	OFF	OFF	.15	.11	.08	OFF	.15	
3	OFF	OFF	.10	.04	.11	OFF	.11	
4	OFF	OFF	.15	.09	.04	OFF	.15	
5	OFF	OFF	.10	.05	.08	OFF	.10	
6	OFF	OFF	.13	.05	.05	OFF	.13	
7	OFF	OFF	.27	.04	.05	OFF	.27	
8	OFF	OFF	.09	.07	.05	OFF	.09	
9	OFF	OFF	.07	.04	.05	OFF	.07	
10	OFF	OFF	.13	.09	.09	OFF	.13	
11	OFF	OFF	.14	.05	.07	OFF	.14	
12	OFF	OFF	.28	.05	.05	OFF	.28	
13	OFF	OFF	.10	.05	.05	OFF	.10	
14	OFF	OFF	.09	.05	.05	OFF	.09	
15	OFF	OFF	.13	.06	.05	OFF	.13	
16	OFF	OFF	.10	.05	.08	OFF	.10	
17	OFF	OFF	.09	.04	.07	OFF	.09	
18	OFF	OFF	.10	.05	.06	OFF	.10	
19	OFF	OFF	.12	.05	.05	OFF	.12	
20	OFF	OFF	.10	.06	.05	OFF	.10	
21	OFF	OFF	.11	.06	.05	OFF	.11	
22	OFF	OFF	.12	.05	.08	OFF	.12	
23	OFF	OFF	.12	.09	.11	OFF	.12	
24	OFF	OFF	.13	.08	.06	OFF	.13	
25	OFF	OFF	.13	.09	.07	OFF	.13	
26	OFF	OFF	.12	.06	.06	OFF	.12	
27	OFF	OFF	.14	.06	.07	OFF	.14	
28	OFF	OFF	.13	.06	.05	OFF	.13	
29	OFF	OFF	.28	.09	.07	OFF	.28	
30	OFF	OFF	.13	.09	.06	OFF	.13	
31	OFF	OFF	.17	.07	.06	OFF	.17	

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers	Yes / No		
Notes:		PRINTED NAME: Ken Hamilton	
		SIGNATURE: <i>Ken Hamilton</i>	DATE: 9/1/22
		PHONE #: (503)843-2176	CERT #: 6303

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

WTP-A

System Name:

SHERIDAN, CITY OF

ID#:OR 4100811

Month/Year:

Aug / 22

Disinfection *Giardia*
Log Inactiv:

0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 6:00 AM	.6	65	39	21.8	7.36	11	YES	550
2 4:00 AM	.6	65	39	20.8	7.37	11	Yes	470
3 6:00 AM	.7	65	45	21.5	7.39	11	Yes	520
4 3:00 AM	.7	65	45	21.8	7.18	11	Yes	570
5 2:00 PM	.8	65	52	20.6	7.18	11	Yes	550
6 4:00 AM	.8	65	52	20.1	7.32	11	Yes	550
7 6:00 AM	.7	65	45	20.5	7.38	11	Yes	550
8 6:00 AM	.7	65	45	20.6	7.39	11	Yes	500
9 6:00 AM	.8	65	52	20.1	7.47	11	Yes	560
10 3:00 AM	.7	65	45	20.8	7.48	11	Yes	480
11 6:00 AM	.7	65	45	20.2	7.44	11	Yes	540
12 6:00 AM	.7	65	45	20.0	7.30	11	YES	550
13 5:00 AM	.6	65	39	19.4	7.48	14	YES	500
14 6:00 AM	.6	65	39	19.1	7.48	14	YES	510
15 6:00 AM	.6	65	39	18.9	7.47	14	YES	350
16 4:00 AM	.6	65	39	18.9	7.46	14	Yes	540
17 4:00 AM	.7	65	45	20.0	7.22	11	Yes	550
18 6:00 AM	.7	65	45	21.3	7.39	11	Yes	500
19 4:00 AM	.7	65	45	22.2	7.22	11	Yes	530
20 6:00 AM	.7	65	45	21.6	7.39	11	Yes	550
21 3:00 AM	.7	65	45	21.1	7.34	11	Yes	530
22 5:00 AM	.7	65	45	21.7	7.36	11	Yes	520
23 7:00 AM	.7	65	45	21.3	7.42	11	YES	500
24 7:00 AM	.7	65	45	20.2	7.47	11	YES	530
25 7:00 AM	.7	65	45	20.2	7.45	11	Yes	470
26 5:00 AM	.7	65	45	21.4	7.40	11	Yes	530
27 6:00 AM	.6	65	39	20.8	7.42	11	Yes	510
28 6:00 AM	.6	65	39	19.6	7.24	14	Yes	500
29 6:00 AM	.7	65	45	19.5	7.42	15	Yes	490
30 6:00 AM	.7	65	45	20.5	7.31	11	Yes	500
31 6:00 AM	.7	65	45	20.1	7.36	11	Yes	510

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013