

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Yamhill**
 Month/Year: **Jun-25**

System Name: City of Sheridan		ID#: 41 00811					WTP : WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	0.100	0.100	0.200	0.200
2	0.100	OFF	OFF	0.125	0.125	OFF	0.125
3	OFF	OFF	0.080	0.125	0.110	OFF	0.125
4	OFF	OFF	0.080	0.090	0.050	OFF	0.090
5	OFF	OFF	OFF	0.100	0.060	OFF	0.100
6	OFF	OFF	0.060	0.060	0.080	OFF	0.080
7	OFF	OFF	OFF	0.080	0.125	OFF	0.125
8	OFF	OFF	0.120	0.090	OFF	OFF	0.120
9	OFF	OFF	0.100	0.120	0.100	0.090	0.120
10	OFF	OFF	0.080	0.070	0.070	OFF	0.080
11	OFF	OFF	0.100	0.080	OFF	OFF	0.100
12	OFF	OFF	0.070	0.070	0.060	0.080	0.080
13	OFF	OFF	0.090	OFF	0.060	OFF	0.090
14	OFF	OFF	OFF	0.060	0.060	OFF	0.060
15	OFF	OFF	OFF	0.070	0.070	OFF	0.070
16	OFF	OFF	0.080	0.070	0.090	0.080	0.090
17	OFF	OFF	0.050	0.055	0.070	OFF	0.070
18	OFF	OFF	0.080	0.070	0.050	OFF	0.080
19	OFF	OFF	0.060	0.055	0.055	OFF	0.060
20	OFF	OFF	0.050	0.050	OFF	OFF	0.050
21	OFF	OFF	OFF	OFF	0.050	OFF	0.050
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	0.070	0.060	0.060	0.070	0.070
24	0.055	0.050	0.050	0.050	0.050	0.060	0.060
25	OFF	OFF	0.050	0.045	0.050	OFF	0.050
26	OFF	OFF	0.050	0.055	0.060	OFF	0.060
27	OFF	OFF	0.050	OFF	OFF	0.050	0.050
28	OFF	OFF	OFF	OFF	0.060	0.055	0.060
29	OFF	OFF	OFF	0.050	OFF	OFF	0.050
30	OFF	OFF	0.055	0.060	0.080	0.120	0.120
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings $\leq$ 0.3 NTU? **✓ Yes / No**
 All 4-hour turbidity readings $\leq$ 1 NTU? **✓ Yes / No**
 All turbidity readings < IFE² triggers **✓ Yes / No**

CT's met everyday?
(see back)
✓ Yes / No

All Cl₂ residual at entry
point $\geq$ 0.2 mg/l?
✓ Yes / No

Notes:

PRINTED NAME: **Lanny S. Sayles**
 SIGNATURE: **[Signature]** DATE: **7-1-25**
 PHONE #: **541-206-3976** CERT #: **6085**

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : WTP-A

System Name: City of Sheridan

ID#: 41 00811

Month/Year: Jun-25

Disinfection
Giardia Log
Inactiv:

0.5

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1038AM	0.898	65	58.4	18.0	7.1	11.5	Yes	345
2	412PM	0.695	65	45.2	17.5	6.8	10.4	Yes	443
3	152AM	0.756	65	49.1	16.8	6.7	10.5	Yes	455
4	532AM	0.727	65	47.3	18.3	6.9	10.0	Yes	296
5	642AM	0.827	65	53.8	18.5	6.9	10.2	Yes	272
6	458AM	0.798	65	51.9	21.2	7.0	8.8	Yes	333
7	1054PM	0.876	65	56.9	20.5	6.8	8.5	Yes	394
8	730PM	0.573	65	37.2	20.5	7.2	9.7	Yes	431
9	737AM	0.566	65	36.8	23.5	7.0	7.2	Yes	406
10	512AM	0.695	65	45.2	21.3	7.4	10.0	Yes	425
11	608PM	0.676	65	43.9	17.1	6.4	9.2	Yes	418
12	418AM	0.646	65	42.0	20.2	7.3	10.3	Yes	455
13	442PM	0.646	65	42.0	18.9	7.2	11.0	Yes	205
14	746PM	0.556	65	36.1	19.5	6.5	7.9	Yes	302
15	740AM	0.534	65	34.7	19.4	6.5	7.9	Yes	321
16	408AM	0.495	65	32.2	19.4	6.8	8.7	Yes	443
17	546AM	0.475	65	30.9	18.9	7.0	9.9	Yes	431
18	224AM	0.456	65	29.6	19.4	6.8	8.7	Yes	425
19	508AM	0.615	65	40.0	19.7	6.9	9.2	Yes	284
20	346AM	0.546	65	35.5	18.1	6.9	10.3	Yes	418
21	148PM	0.585	65	38.0	18.3	7.2	11.1	Yes	266
22	456AM	0.585	65	38.0	18.1	6.8	9.6	Yes	40
23	440PM	0.544	65	35.4	18.1	6.8	9.6	Yes	418
24	404PM	0.637	65	41.4	20.0	6.7	8.2	Yes	437
25	406PM	0.615	65	40.0	20.1	6.6	7.9	Yes	406
26	500AM	0.615	65	40.0	20.1	6.6	7.9	Yes	278
27	1134AM	0.727	65	47.3	19.7	7.0	9.5	Yes	290
28	232PM	0.615	65	40.0	19.9	6.9	9.1	Yes	290
29	652PM	0.534	65	34.7	21.7	6.9	8.0	Yes	321
30	500am	0.514	65	33.4	20.8	6.9	8.5	Yes	437
31			65					No	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013