

OHA - Drinking Water Services -Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Yamhill
Month/Year: Nov. 2025

System Name: City of Sheridan		ID#: 41 00811					WTP : WTP-A
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	0.040	0.050	0.060	OFF	0.060
4	OFF	OFF	OFF	0.040	0.035	OFF	0.040
5	OFF	OFF	OFF	0.050	0.050	0.060	0.060
6	0.100	OFF	0.050	0.040	0.030	OFF	0.050
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	0.040	0.090	0.040	OFF	0.090
11	OFF	OFF	OFF	0.040	OFF	OFF	0.040
12	OFF	OFF	0.030	0.030	0.030	OFF	0.030
13	OFF	OFF	0.030	OFF	OFF	OFF	0.030
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	0.030	0.030	OFF	0.030
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	0.040	0.040	0.045	0.135	0.040	OFF	0.135
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	0.030	0.040	OFF	OFF	0.040
21	OFF	OFF	0.040	0.040	0.050	OFF	0.050
22	OFF	OFF	0.040	OFF	OFF	OFF	0.040
23	OFF	OFF	OFF	0.040	OFF	OFF	0.040
24	OFF	OFF	0.030	0.035	0.030	OFF	0.035
25	OFF	OFF	0.030	0.040	0.080	OFF	0.080
26	OFF	OFF	0.035	OFF	OFF	OFF	0.035
27	OFF	OFF	OFF	OFF	OFF	0.100	0.100
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	OFF	0.035	0.040	0.040
31							

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU? ☒ Yes / ☐ No
 All 4-hour turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No
 All turbidity readings < IFE² triggers ☒ Yes / ☐ No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) ☒ Yes / ☐ No
 All Cl₂ residual at entry point $\geq$ 0.2 mg/l? ☒ Yes / ☐ No

Notes:

PRINTED NAME: Lonny S. Sayles
 SIGNATURE: *Lonny S. Sayles* DATE: 12-1-25
 PHONE #: 541-266-3976 CERT #: 6085

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Indiv. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : WTP-A

System Name: City of Sheridan

ID#: 41 00811

Month/Year: Nov-25

Disinfection
Giardia Log
Inactiv:

0.5

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	417AM	0.69	65	44.9	10.4	7.0	18.1	Yes	34
2	347AM	0.713	65	46.3	10.2	7.0	18.3	Yes	46
3	432PM	0.703	65	45.7	10.2	7.0	18.3	Yes	260
4	242PM	0.663	65	43.1	10.1	7.0	18.4	Yes	327
5	1155AM	0.581	65	37.8	10.3	7.0	17.8	Yes	376
6	729AM	0.672	65	43.7	10.4	6.9	17.8	Yes	247
7	633AM	0.642	65	41.7	10.6	7.0	17.6	Yes	34
8	729AM	0.672	65	43.7	10.5	7.0	17.7	Yes	34
9	327AM	0.663	65	43.1	10.5	7.0	17.7	Yes	40
10	141PM	0.671	65	43.6	10.6	6.9	17.5	Yes	412
11	613AM	0.682	65	44.3	10.6	6.9	17.4	Yes	260
12	528AM	0.79	65	51.4	10.5	7.0	18.4	Yes	266
13	201PM	0.802	65	52.1	10.6	7.0	18.3	Yes	247
14	608AM	0.907	65	59.0	10.6	7.0	18.6	Yes	101
15	829AM	0.867	65	56.4	11.1	7.1	18.2	Yes	260
16	703AM	0.935	65	60.8	10.9	7.1	18.6	Yes	211
17	1209PM	0.976	65	63.4	10.9	7.1	18.9	Yes	272
18	1054AM	0.908	65	59.0	10.4	7.1	19.3	Yes	162
19	301PM	0.876	65	56.9	10.1	7.1	19.5	Yes	144
20	1134PM	0.85	65	55.3	10.0	7.1	19.8	Yes	357
21	733PM	0.821	65	53.4	9.6	7.1	20.2	Yes	376
22	618PM	0.821	65	53.4	9.1	7.1	20.8	Yes	247
23	904PM	0.811	65	52.7	8.9	7.1	21.0	Yes	217
24	844PM	0.811	65	52.7	8.7	7.1	21.3	Yes	229
25	623AM	0.811	65	52.7	8.5	7.1	21.6	Yes	376
26	929PM	0.811	65	52.7	8.4	7.1	21.6	Yes	180
27	226PM	0.79	65	51.4	8.6	7.1	21.1	Yes	192
28	316PM	0.802	65	52.1	9.8	7.0	19.2	Yes	144
29	949AM	0.782	65	50.8	8.6	7.0	20.5	Yes	144
30	733AM	0.803	65	52.2	8.8	7.0	20.7	Yes	266
31			65					No	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013