

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Yamhill**
 Month/Year: **DEC. 2025**

System Name: **City of Sheridan** ID#: **41 00811** WTP : **WTP-A**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.035	OFF	0.030	0.030	OFF	OFF	0.030
2	OFF	OFF	OFF	OFF	0.035	OFF	0.035
3	OFF	OFF	0.030	OFF	0.080	OFF	0.080
4	OFF	OFF	0.025	OFF	OFF	OFF	0.025
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	0.035	0.035
8	OFF	OFF	0.024	0.030	OFF	OFF	0.030
9	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	0.100	0.040	0.040	0.040	0.100
23	0.040	0.040	OFF	OFF	OFF	OFF	0.040
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All turbidity readings < IFE ² triggers	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:

PRINTED NAME: Lonny S. Sayles
SIGNATURE: *[Signature]* **DATE:** 1-5-26
PHONE #: 541-206-3976 **CERT #:** 6085

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :	WTP-A
Disinfection <i>Giardia</i> Log Inactiv:	0.5

System Name: City of Sheridan ID#: 41 00811 Month/Year: Dec-25

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	653AM	0.811	65	52.7	8.4	7.0	21.1	Yes	260
2	622AM	0.877	65	57.0	8.2	7.0	21.5	Yes	266
3	623AM	0.85	65	55.3	8.3	7.0	21.3	Yes	247
4	622AM	0.869	65	56.5	8.2	7.0	21.5	Yes	241
5	822AM	0.838	65	54.5	8.2	7.0	21.4	Yes	70
6	1109PM	0.86	65	55.9	8.4	7.0	21.1	Yes	34
7	707AM	0.82	65	53.3	8.6	7.0	20.6	Yes	228
8	1124PM	0.829	65	53.9	9.1	7.0	19.8	Yes	241
9	425PM	0.791	65	51.4	9.0	6.9	19.7	Yes	46
10	1139PM	0.802	65	52.1	9.3	7.0	19.5	Yes	70
11	627AM	0.771	65	50.1	9.5	6.9	18.9	Yes	21
12	1124PM	0.771	65	50.1	9.3	6.9	19.2	Yes	15
13	727AM	0.74	65	48.1	9.1	6.9	19.2	Yes	15
14	812AM	0.754	65	49.0	9.0	6.9	19.4	Yes	27
15	627AM	0.722	65	46.9	9.3	6.9	18.8	Yes	27
16	2349PM	0.722	65	46.9	9.3	6.9	18.9	Yes	27
17	1204PM	0.703	65	45.7	9.4	6.9	18.6	Yes	76
18	1023PM	0.714	65	46.4	9.1	6.9	19.1	Yes	46
19	612AM	0.68	65	44.2	8.8	7.0	20.3	Yes	2168
20	1000AM	0.53	65	34.5	8.7	6.7	18.0	Yes	370
21	840AM	0.643	65	41.8	8.6	6.7	18.2	Yes	21
22	425AM	0.685	65	44.5	8.5	6.6	17.7	Yes	21
23	756AM	0.692	65	45.0	9.3	7.0	19.3	Yes	345
24	907PM	0.949	65	61.7	8.4	7.0	21.1	Yes	205
25	837AM	0.917	65	59.6	8.5	6.8	19.4	Yes	3
26	1123AM	0.96	65	62.4	8.4	6.7	19.3	Yes	15
27	917AM	0.928	65	60.3	8.2	6.7	19.2	Yes	9
28	948PM	0.96	65	62.4	8.1	6.7	19.4	Yes	15
29	134PM	0.949	65	61.7	7.9	6.7	19.9	Yes	15
30	1043PM	0.9	65	58.5	7.9	6.7	19.9	Yes	40
31	1203AM	0.9	65	58.5	7.8	6.8	20.2	Yes	21

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013