

OHA - Drinking Water Services -Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Yamhill
 Month/Year: Feb. 2026

System Name: City of Sheridan ID#: 41 00811 WTP : WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	OFF	OFF	0.035	OFF	OFF	OFF	0.035
2	OFF	OFF	0.050	0.080	0.035	0.130	0.130
3	OFF	OFF	0.030	OFF	0.035	0.035	0.035
4	OFF	OFF	OFF	OFF	OFF	0.070	0.070
5	OFF	OFF	OFF	0.055	0.030	OFF	0.030
6	OFF	OFF	OFF	0.035	0.060	OFF	0.060
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	0.040	0.050	OFF	0.050
9	OFF	OFF	OFF	0.040	0.070	OFF	0.070
10	OFF	OFF	OFF	0.050	OFF	OFF	0.050
11	OFF	OFF	OFF	OFF	0.050	OFF	0.050
12	OFF	OFF	OFF	OFF	0.040	OFF	0.040
13	OFF	OFF	0.040	0.040	OFF	OFF	0.040
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	0.045	0.050	OFF	0.050
17	OFF	OFF	OFF	OFF	0.040	OFF	0.040
18	OFF	OFF	OFF	OFF	0.040	OFF	0.040
19	OFF	OFF	OFF	OFF	0.040	OFF	0.040
20	OFF	OFF	0.056	0.060	OFF	OFF	0.060
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29							
30							
31							

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No
 All 4-hour turbidity readings ≤ 1 NTU? Yes / No
 All turbidity readings < IFE² triggers Yes / No

CT's met everyday? (see back) Yes / No
 All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

Notes:

PRINTED NAME: Lonny S. Sayle
 SIGNATURE: *Lonny S. Sayle* DATE: 3-2-26
 PHONE #: 541-266-3976 CERT #: 6085

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : WTP-A

System Name: City of Sheridan

ID#: 41 00811

Month/Year: Feb.2026

**Disinfection
Giardia Log
Inactiv:**

0.5

Date	Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]	formula	Yes / No	[GPM]	
1	806AM	0.887	65	57.7	7.3	6.9	21.9	Yes	168
2	736AM	0.887	65	57.7	7.6	7.0	22.1	Yes	296
3	329PM	0.838	65	54.5	7.7	7.0	22.1	Yes	266
4	1048PM	0.86	65	55.9	7.9	7.0	21.8	Yes	260
5	1053AM	0.838	65	54.5	8.1	7.0	21.3	Yes	260
6	325PM	0.868	65	56.4	8.1	7.0	21.3	Yes	260
7	937PM	0.838	65	54.5	7.8	6.9	21.4	Yes	34
8	1028PM	0.704	65	45.8	7.9	7.0	21.1	Yes	266
9	104PM	0.642	65	41.7	8.2	6.9	20.4	Yes	254
10	104PM	0.872	65	56.7	8.3	6.9	20.6	Yes	254
11	330PM	0.753	65	48.9	8.3	6.9	20.2	Yes	247
12	435PM	0.81	65	52.7	8.2	6.9	20.4	Yes	211
13	741AM	0.877	65	57.0	7.9	6.9	21.2	Yes	278
14	1002PM	0.949	65	61.7	7.7	6.9	21.4	Yes	21
15	505PM	0.936	65	60.8	7.7	6.9	21.3	Yes	364
16	1027PM	1.009	65	65.6	7.7	6.9	21.9	Yes	272
17	204PM	1	65	65.0	7.5	6.9	22.1	Yes	235
18	224PM	1.009	65	65.6	7.3	6.9	22.4	Yes	217
19	219PM	1	65	65.0	7.2	6.9	22.5	Yes	241
20	1002PM	1.018	65	66.2	7.1	6.9	22.9	Yes	260
21	1031PM	1	65	65.0	7.2	6.9	22.6	Yes	21
22	1007PM	0.977	65	63.5	7.2	6.9	22.5	Yes	27
23	942PM	0.937	65	60.9	7.5	6.9	21.6	Yes	9
24	846AM	0.812	65	52.8	7.3	6.8	21.2	Yes	9
25	445pm	0.898	65	58.4	7.9	6.8	20.4	Yes	15
26	746pm	0.927	65	60.3	7.8	6.8	20.6	Yes	15
27	329PM	0.927	65	60.3	7.9	6.8	20.3	Yes	70
28	912PM	0.949	65	61.7	7.6	6.8	20.7	Yes	15
29			65					No	
30			65					No	
31			65					No	

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013