

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Yamhill  
 Month/Year: Mar-26

System Name:	City of Sheridan			ID#: 41 00811	WTP : WTP-A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	OFF	OFF	0.035	OFF	0.035
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12	OFF	OFF	OFF	OFF	OFF	OFF	OFF
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	OFF	OFF	OFF	OFF	OFF
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	OFF	OFF	0.030	OFF	OFF	0.030
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	OFF	OFF	OFF	OFF	OFF
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	OFF	OFF	OFF	OFF	OFF
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF
31	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		

Notes:	PRINTED NAME: Lanny S. Styles	
	SIGNATURE: <i>Lanny S. Styles</i>	DATE: 4-1-26
	PHONE #: 541-206-3976	CERT #: 6085

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

WTP - : WTP-A

System Name: City of Sheridan

ID#: 41 00811

Month/Year: Mar-26

Disinfection  
Giardia Log  
Inactiv:

0.5

Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	952PM	0.958	65	62.3	7.8	6.8	20.5	Yes	21
2	420PM	0.976	65	63.4	8.1	6.8	20.0	Yes	9
3	404PM	0.958	65	62.3	8.1	6.8	19.9	Yes	15
4	604PM	0.976	65	63.4	8.0	6.8	20.1	Yes	9
5	951PM	0.959	65	62.3	7.9	6.8	20.2	Yes	15
6	800PM	0.987	65	64.2	8.0	6.8	20.1	Yes	113
7	434PM	0.966	65	62.8	8.6	6.8	19.4	Yes	21
8	820PM	0.999	65	64.9	8.2	6.8	19.9	Yes	21
9	353PM	0.976	65	63.4	8.3	6.8	19.8	Yes	131
10	930PM	1.009	65	65.6	8.1	6.8	20.2	Yes	21
11	4.23PM	1	65	65.0	8.3	6.8	20.0	Yes	18
12	905AM	0.763	65	49.6	8.1	6.7	19.3	Yes	9
13	1201AM	0.782	65	50.8	8.3	6.6	18.5	Yes	0
14	906AM	0.908	65	59.0	8.5	6.6	18.4	Yes	0
15	454PM	1	65	65.0	8.2	6.6	18.8	Yes	0
16	1141PM	0.966	65	62.8	9.0	6.6	17.9	Yes	0
17	418AM	0.916	65	59.5	8.9	6.6	18.0	Yes	0
18	714PM	0.875	65	56.9	8.9	6.7	18.2	Yes	46
19	1211PM	0.782	65	50.8	9.0	6.7	17.9	Yes	46
20	503PM	0.828	65	53.8	8.9	6.7	18.2	Yes	15
21	629AM	0.907	65	59.0	9.2	6.7	18.1	Yes	9
22	739PM	1.034	65	67.2	9.0	6.7	18.7	Yes	9
23	743PM	1.016	65	66.0	8.8	6.7	19.0	Yes	34
24	643PM	1.048	65	68.1	8.8	6.7	19.0	Yes	9
25	352PM	1.027	65	66.8	8.9	6.7	19.0	Yes	9
26	643PM	1.074	65	69.8	9.0	6.8	19.0	Yes	27
27	527PM	1.034	65	67.2	9.1	6.8	18.9	Yes	27
28	748PM	1.065	65	69.2	9.2	6.8	18.8	Yes	21
29	347PM	1.035	65	67.3	8.8	6.8	19.2	Yes	27
30	658PM	1.083	65	70.4	9.0	6.8	19.2	Yes	27
31	922PM	1.047	65	68.1	8.9	6.8	19.3	Yes	15

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013