

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: **MARION**  
 Month/Year: **Feb-26**

Conventional or Direct Filtration

System Name:	SILVERTON, CITY OF		ID#: 4100823	WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	OFF	OFF	0.09	OFF	0.04	0.06	0.19
2	OFF	OFF	0.07	0.04	OFF	0.05	0.14
3	OFF	OFF	0.06	0.04	OFF	0.09	0.20
4	0.05	OFF	0.05	0.05	0.04	OFF	0.15
5	0.10	OFF	0.06	0.04	0.07	OFF	0.18
6	0.22	OFF	0.12	0.04	0.07	0.08	0.19
7	OFF	OFF	0.06	OFF	0.10	0.05	0.18
8	OFF	OFF	0.07	0.06	OFF	0.06	0.16
9	OFF	OFF	0.09	0.11	OFF	0.07	0.17
10	0.11	OFF	OFF	0.07	OFF	0.13	0.24
11	0.08	OFF	OFF	0.09	0.06	0.08	0.15
12	0.10	OFF	0.09	0.06	OFF	0.08	0.16
13	0.05	OFF	0.05	OFF	0.09	0.06	0.20
14	OFF	OFF	0.08	OFF	0.14	0.05	0.28
15	OFF	OFF	0.07	0.06	OFF	0.08	0.18
16	OFF	0.06	0.09	0.07	0.08	0.07	0.16
17	0.10	OFF	0.08	0.07	0.07	0.10	0.14
18	OFF	OFF	OFF	0.10	0.05	0.05	0.17
19	0.07	OFF	0.05	0.06	0.06	0.06	0.19
20	OFF	OFF	0.07	0.06	OFF	0.08	0.10
21	OFF	0.09	0.04	0.05	0.04	OFF	0.13
22	0.05	OFF	0.14	0.05	0.21	0.10	0.21
23	0.06	OFF	0.09	0.06	OFF	0.09	0.14
24	0.14	OFF	0.21	OFF	0.11	0.12	0.23
25	OFF	OFF	0.09	0.22	0.25	0.20	0.29
26	0.26	0.07	OFF	0.06	0.12	OFF	0.26
27	0.28	OFF	0.17	0.10	OFF	0.06	0.28
28	0.27	OFF	0.22	0.09	0.13	0.12	0.27
29							
30							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? All 4-hour turbidity readings ≤ 1 NTU? All turbidity readings < IFE <sup>2</sup> triggers	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<b>Notes:</b>	<b>Darrel Lockard</b> SIGNATURE <i>Darrel Lockard</i> DATE: 03/10/26 Phone Number: (541)2229997      CERT #: 2853	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	SILVERTON, CITY OF	ID#: 41	00823	Month/Year:	Jan-26	Disinfection <i>Giardia</i> Log Inactiv:	1
--------------	--------------------	---------	-------	-------------	--------	--	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1 / 03:52	0.73	494	360.6	8.8	7.42	46.9	YES	495
2 / 15:06	0.72	481	346.3	9.6	7.27	42.2	YES	638
3 / 08:41	0.77	422	324.9	9.3	7.26	43.1	YES	541
4 / 10:52	0.76	455	345.8	9.7	7.27	42.1	YES	580
5 / 09:35	0.69	480	331.2	9.8	7.29	41.8	YES	515
6 / 20:23	0.78	424	330.7	9.4	7.22	42.3	YES	410
7 / 22:19	0.83	430	356.9	9.1	7.25	43.8	YES	391
8 / 19:26	0.79	481	380.0	9.4	7.21	42.2	YES	541
9 / 21:46	0.83	484	401.7	10.4	7.04	37.4	YES	573
10 / 02:52	0.87	501	435.9	10.2	7.22	40.5	YES	547
11 / 23:02	0.79	497	392.6	10.2	7.46	43.7	YES	560
12 / 07:21	0.81	480	388.8	10.3	7.49	44.0	YES	488
13 / 21:09	0.8	489	391.2	10.0	8.09	55.4	YES	391
14 / 15:25	0.81	500	405.0	9.6	7.68	49.2	YES	378
15 / 02:31	0.74	482	356.7	10.4	7.93	50.6	YES	449
16 / 09:53	0.81	499	404.2	9.8	7.89	52.4	YES	560
17 / 16:09	0.76	502	381.5	9.2	6.99	39.4	YES	547
18 / 08:51	0.81	487	394.5	9.0	6.98	40.0	YES	528
19 / 19:04	0.83	423	351.1	10.0	7.21	40.7	YES	534
20 / 02:40	0.78	426	332.3	8.3	7.27	46.3	YES	391
21 / 18:09	0.75	469	351.8	8.6	7.39	47.2	YES	397
22 / 13:15	0.76	423	321.5	9.1	7.27	43.8	YES	495
23 / 07:52	0.79	424	335.0	8.8	7.29	45.1	YES	521
24 / 21:22	0.76	471	358.0	9.4	7.25	42.6	YES	515
25 / 16:20	0.8	458	366.4	9.6	7.22	41.8	YES	528
26 / 10:01	0.82	481	394.4	9.6	7.36	44.0	YES	515
27 / 13:25	0.78	475	370.5	9.1	7.30	44.3	YES	430
28 / 08:10	0.88	465	409.2	9.0	6.81	38.0	YES	410
29								
30								
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013