


| OHA - Drinking Water Services - Surface Water Quality Data Form |                          |                  |       |                            |                               | County:                                       | LANE  |
|---|--------------------------|------------------|-------|----------------------------|-------------------------------|---|-------|
| Cartridge or Bag Filtration                                     |                          |                  |       |                            |                               | Month/Year:                                   | 11/22 |
| System Name:  | SHANRI LA WATER DISTRICT |                  |       | ID#: 41                    | 00835                         | WTP ID: TP-                                   |       |
| Day   | PSI Before Filter        | PSI After Filter | PSID  | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day <sup>1</sup> [NTU] |       |
| 1   |                          |                  |       | 25.00                      | 0.11                          | 0.11  |       |
| 2   |                          |                  |       | 25.00                      | 0.09                          | 0.09  |       |
| 3   |                          |                  |       | 25.00                      | 0.09                          | 0.09  |       |
| 4   | 15.50                    | 7.50             | 8.00  | 25.00                      | 0.09                          | 0.09  |       |
| 5   |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 6   |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 7   | 15.50                    | 7.50             | 8.00  | 25.00                      | 0.10                          | 0.10  |       |
| 8   | 14.00                    | 7.00             | 7.00  | 25.00                      | 0.11                          | 0.11  |       |
| 9   | 16.00                    | 7.50             | 8.50  | 25.00                      | 0.09                          | 0.09  |       |
| 10  |                          |                  |       | 25.00                      | 0.09                          | 0.09  |       |
| 11  |                          |                  |       | 25.00                      | 0.09                          | 0.09  |       |
| 12  |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 13  |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 14  |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 15  |                          |                  |       | 25.00                      | 0.11                          | 0.11  |       |
| 16  |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 17  | 14.00                    | 7.00             | 7.00  | 25.00                      | 0.08                          | 0.08  |       |
| 18  |                          |                  |       | 25.00                      | 0.09                          | 0.09  |       |
| 19  |                          |                  |       | 25.00                      | 0.09                          | 0.09  |       |
| 20  | 14.00                    | 7.00             | 7.00  | 25.00                      | 0.09                          | 0.09  |       |
| 21  |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 22  | 14.50                    | 7.00             | 7.50  | 25.00                      | 0.10                          | 0.10  |       |
| 23  | 17.50                    | 7.50             | 10.00 | 25.00                      | 0.10                          | 0.10  |       |
| 24  |                          |                  |       | 25.00                      | 0.09                          | 0.09  |       |
| 25  | 16.50                    | 7.00             | 9.50  | 25.00                      | 0.09                          | 0.09  |       |
| 26  |                          |                  |       | 25.00                      | 0.09                          | 0.09  |       |
| 27  | 20.50                    | 7.50             | 13.00 | 25.00                      | 0.10                          | 0.10  |       |
| 28  |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 29  |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 30  |                          |                  |       | 25.00                      | 0.10                          | 0.10  |       |
| 31  |                          |                  |       |                            |                               |   |       |

| Cartridge & Bag Filtration               |   | Monthly Summary (Answer Yes or No)                              |   |
|--|---|---|---|
| 95% of daily turbidity readings ≤ 1 NTU? | <input checked="" type="radio"/> Yes / <input type="radio"/> No | CT's met everyday? (see back)                                   | All Cl2 residual at entry point ≥ 0.2 mg/l?                     |
| All daily turbidity readings ≤ 5 NTU?    | <input checked="" type="radio"/> Yes / <input type="radio"/> No | <input checked="" type="radio"/> Yes / <input type="radio"/> No | <input checked="" type="radio"/> Yes / <input type="radio"/> No |

Notes: PSI = pounds per square inch  
PSID = pounds per square inch difference (before filter - after filter)  
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Anthony Morales  
SIGNATURE:   
DATE: 12-9-22  
PHONE #: (541) 554-8040  
CERT #:

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

Eric Carlson 12-5-22 7-09011

| OHA - Drinking Water Services - Surface Water Quality Data Form |   |                     |           |             |       |   | WTP - :              |                                  |
|---|---|---------------------|-----------|-------------|-------|---|----------------------|----------------------------------|
| System Name:  | SHANRI LA WATER DISTRICT  | ID#: 41             | 00835     | Month/Year: | 11/22 | Disinfection <i>Giardia</i><br>Log Inactiv: | 1                    |                                  |
| Date / Time   | Minimum Cl <sub>2</sub><br>Residual at 1st<br>User ( C ) <sup>2</sup> | Contact Time<br>(T) | Actual CT | Temp        | pH    | Required CT                                 | CT Met? <sup>2</sup> | Peak<br>Hourly<br>Demand<br>Flow |
|   | [ppm or mg/L]   | [minutes]           | C X T     | [° C]       |       | formula                                     | Yes / No             | [GPM]                            |
| 1   | 0.67  | 195                 | 130.7     | 15.0        | 7.50  | 31.6  | YES                  |                                  |
| 2   | 0.60  | 195                 | 117.0     | 14.0        | 7.60  | 34.7  | YES                  |                                  |
| 3   | 0.71  | 195                 | 138.5     | 14.0        | 7.60  | 35.2  | YES                  |                                  |
| 4   | 0.66  | 195                 | 128.7     | 14.0        | 7.50  | 33.7  | YES                  |                                  |
| 5   | 0.66  | 195                 | 128.7     | 14.0        | 7.70  | 36.3  | YES                  |                                  |
| 6   | 0.67  | 195                 | 130.7     | 14.0        | 7.60  | 35.0  | YES                  |                                  |
| 7   | 0.66  | 195                 | 128.7     | 13.0        | 7.50  | 36.0  | YES                  |                                  |
| 8   | 0.67  | 195                 | 130.7     | 12.0        | 7.60  | 40.2  | YES                  |                                  |
| 9   | 0.67  | 195                 | 130.7     | 13.0        | 7.60  | 37.4  | YES                  |                                  |
| 10  | 0.65  | 195                 | 126.8     | 13.0        | 7.50  | 36.0  | YES                  |                                  |
| 11  | 0.66  | 195                 | 128.7     | 13.0        | 7.50  | 36.0  | YES                  |                                  |
| 12  | 0.65  | 195                 | 126.8     | 13.0        | 7.50  | 36.0  | YES                  |                                  |
| 13  | 0.65  | 195                 | 126.8     | 13.0        | 7.50  | 36.0  | YES                  |                                  |
| 14  | 0.64  | 195                 | 124.8     | 12.0        | 7.50  | 38.7  | YES                  |                                  |
| 15  | 0.65  | 195                 | 126.8     | 12.0        | 7.40  | 37.4  | YES                  |                                  |
| 16  | 0.64  | 195                 | 124.8     | 12.0        | 7.40  | 37.4  | YES                  |                                  |
| 17  | 0.63  | 195                 | 122.9     | 12.0        | 7.50  | 38.7  | YES                  |                                  |
| 18  | 0.64  | 195                 | 124.8     | 12.0        | 7.40  | 37.4  | YES                  |                                  |
| 19  | 0.64  | 195                 | 124.8     | 12.0        | 7.40  | 37.4  | YES                  |                                  |
| 20  | 0.65  | 195                 | 126.8     | 12.0        | 7.40  | 37.4  | YES                  |                                  |
| 21  | 0.64  | 195                 | 124.8     | 12.0        | 7.50  | 38.7  | YES                  |                                  |
| 22  | 0.64  | 195                 | 124.8     | 12.0        | 7.50  | 38.7  | YES                  |                                  |
| 23  | 0.63  | 195                 | 122.9     | 13.0        | 7.40  | 34.6  | YES                  |                                  |
| 24  | 0.61  | 195                 | 119.0     | 12.0        | 7.40  | 37.3  | YES                  |                                  |
| 25  | 0.66  | 195                 | 128.7     | 12.0        | 7.40  | 37.5  | YES                  |                                  |
| 26  | 0.64  | 195                 | 124.8     | 12.0        | 7.50  | 38.7  | YES                  |                                  |
| 27  | 0.62  | 195                 | 120.9     | 12.0        | 7.50  | 38.6  | YES                  |                                  |
| 28  | 0.67  | 195                 | 130.7     | 11.0        | 7.60  | 42.9  | YES                  |                                  |
| 29  | 0.65  | 195                 | 126.8     | 11.0        | 7.60  | 42.8  | YES                  |                                  |
| 30  | 0.64  | 195                 | 124.8     | 11.0        | 7.50  | 41.3  | YES                  |                                  |
| 31  |   |                     |           |             |       |   |                      |                                  |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350