


OHA - Drinking Water Services - Surface Water Quality Data Form					County:	LANE
Cartridge or Bag Filtration					Month/Year:	10/23
System Name:	SHANGRI LA WATER DISTRICT			ID#: 41	00835	WTP ID: TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1				25.00	0.13	0.13
2				25.00	0.13	0.13
3				25.00	0.12	0.12
4	9.00	7.00	2.00	25.00	0.12	0.12
5	9.50	7.00	2.50	25.00	0.14	0.14
6	9.00	7.00	2.00	25.00	0.12	0.12
7	9.00	7.00	2.00	25.00	0.12	0.12
8	9.50	7.00	2.50	25.00	0.12	0.12
9	9.00	7.00	2.00	25.00	0.13	0.13
10	9.50	7.00	2.50	25.00	0.13	0.13
11				25.00	0.12	0.12
12				25.00	0.12	0.12
13				25.00	0.13	0.13
14				25.00	0.13	0.13
15				25.00	0.14	0.14
16	9.50	7.00	2.50	25.00	0.16	0.16
17	9.00	7.00	2.00	25.00	0.15	0.15
18				25.00	0.13	0.13
19				25.00	0.13	0.13
20				25.00	0.12	0.12
21				25.00	0.12	0.12
22				25.00	0.13	0.13
23				25.00	0.14	0.14
24	10.00	7.00	3.00	25.00	0.13	0.13
25	9.50	7.00	2.50	25.00	0.13	0.13
26	10.00	7.00	3.00	25.00	0.13	0.13
27				25.00	0.13	0.13
28				25.00	0.13	0.13
29				25.00	0.12	0.12
30				25.00	0.12	0.12
31				25.00	0.12	0.12
Cartridge & Bag Filtration				Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings \leq 1 NTU?				<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point \geq 0.2 mg/l?
All daily turbidity readings \leq 5 NTU?				<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch				PRINTED NAME: Anthony Morales		
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE: 		DATE: 11/3/23
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				PHONE #: (541) 554-8040		CERT #:
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.						
Eric Carlson 11/6/23						

OHA - Drinking Water Services - Surface Water Quality Data Form							WTP - :	
System Name:	SHANGRI LA WATER DISTRICT	ID#: 41	00835	Month/Year:	10/23	Disinfection <i>Giardia</i> Log Inactiv:	1	
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.68	195	132.6	14.0	7.60	35.1	YES	
2	0.67	195	130.7	14.0	7.80	37.7	YES	
3	0.67	195	130.7	14.0	7.80	37.7	YES	
4	0.69	195	134.6	14.0	7.70	36.4	YES	
5	0.68	195	132.6	14.0	7.90	39.2	YES	
6	0.66	195	128.7	14.0	7.90	39.1	YES	
7	0.66	195	128.7	14.0	7.80	37.7	YES	
8	0.66	195	128.7	15.0	7.80	35.2	YES	
9	0.62	195	120.9	15.0	7.80	35.1	YES	
10	0.66	195	128.7	14.0	7.40	32.5	YES	
11	0.65	195	126.8	14.0	7.90	39.0	YES	
12	0.65	195	126.8	14.0	7.90	39.0	YES	
13	0.64	195	124.8	14.0	7.90	39.0	YES	
14	0.64	195	124.8	14.0	7.80	37.6	YES	
15	0.63	195	122.9	14.0	7.80	37.5	YES	
16	0.64	195	124.8	14.0	7.70	36.2	YES	
17	0.63	195	122.9	14.0	7.80	37.5	YES	
18	0.63	195	122.9	14.0	7.80	37.5	YES	
19	0.65	195	126.8	14.0	7.70	36.3	YES	
20	0.64	195	124.8	14.0	7.70	36.2	YES	
21	0.65	195	126.8	14.0	7.60	34.9	YES	
22	0.63	195	122.9	14.0	7.60	34.9	YES	
23	0.62	195	120.9	14.0	7.50	33.6	YES	
24	0.60	195	117.0	13.0	7.60	37.1	YES	
25	0.58	195	113.1	13.0	7.50	35.7	YES	
26	0.56	195	109.2	13.0	7.50	35.6	YES	
27	0.55	195	107.3	13.0	7.60	36.9	YES	
28	0.54	195	105.3	12.0	7.50	38.3	YES	
29	0.54	195	105.3	12.0	7.70	41.0	YES	
30	0.49	195	95.6	11.0	7.60	42.1	YES	
31	0.51	195	99.5	11.0	7.60	42.2	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350