



OHA - Drinking Water Services - Surface Water Quality Data Form					County:	LANE
Cartridge or Bag Filtration					Month/Year:	12/24
System Name:	SHANGRI LA WAYER DISTRICT			ID#: 41	00835	WTP ID: TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1				25.00	0.16	0.16
2				25.00	0.17	0.17
3	11.50	7.50	4.00	25.00	0.15	0.15
4	11.50	7.50	4.00	25.00	0.15	0.15
5				25.00	0.17	0.17
6				25.00	0.13	0.13
7				25.00	0.15	0.15
8	11.50	7.50	4.00	25.00	0.15	0.15
9				25.00	0.17	0.17
10				25.00	0.17	0.17
11	11.50	7.50	4.00	25.00	0.13	0.13
12				25.00	0.15	0.15
13				25.00	0.13	0.13
14				25.00	0.13	0.13
15	11.00	7.50	3.50	25.00	0.15	0.15
16				25.00	0.15	0.15
17				25.00	0.17	0.17
18	12.00	7.50	4.50	25.00	0.13	0.13
19	12.00	7.50	4.50	25.00	0.13	0.13
20				25.00	0.15	0.15
21				25.00	0.15	0.15
22				25.00	0.17	0.17
23	12.00	7.50	4.50	25.00	0.15	0.15
24	11.50	7.50	4.00	25.00	0.15	0.15
25				25.00	0.16	0.16
26				25.00	0.13	0.13
27				25.00	0.17	0.17
28	12.00	7.50	4.50	25.00	0.17	0.17
29				25.00	0.15	0.15
30				25.00	0.13	0.13
31				25.00	0.13	0.13
Cartridge & Bag Filtration				Monthly Summary (Answer Yes or No)		
95% of daily turbidity readings ≤ 1 NTU?				<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch				PRINTED NAME: Anthony Morelas		
PSID = pounds per square inch difference (before filter - after filter)				SIGNATURE: 		DATE: 1-2-25
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.				PHONE #: (541) 554-8040		CERT #: T-09011
<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.						
 1-6-25						

## OHA - Drinking Water Services - Surface Water Quality Data Form

WTP :

System Name:	SHANGRI LA WAYER DISTRICT		ID#: 41	00835	Month/Year:	12/24	Disinfection <i>Giardia</i> Log Inactiv:	1
Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.97	195	189.2	9.5	7.80	52.7	YES	
2	0.97	195	189.2	9.3	7.80	53.4	YES	
3	0.90	195	175.5	9.5	7.90	54.2	YES	
4	0.90	195	175.5	9.0	7.90	56.0	YES	
5	0.88	195	171.6	8.8	8.00	58.7	YES	
6	0.86	195	167.7	9.0	8.00	57.8	YES	
7	0.84	195	163.8	9.0	7.70	51.8	YES	
8	0.84	195	163.8	9.0	7.70	51.8	YES	
9	0.84	195	163.8	9.0	7.70	51.8	YES	
10	0.85	195	165.8	9.0	7.60	50.0	YES	
11	0.83	195	161.9	9.0	7.60	49.9	YES	
12	0.78	195	152.1	9.0	7.60	49.6	YES	
13	0.86	195	167.7	9.5	7.60	48.5	YES	
14	0.80	195	156.0	9.5	7.50	46.5	YES	
15	0.78	195	152.1	9.0	7.50	47.9	YES	
16	0.75	195	146.3	10.0	7.50	44.7	YES	
17	0.94	195	183.3	9.5	7.50	47.2	YES	
18	0.89	195	173.6	10.0	7.60	47.0	YES	
19	0.92	195	179.4	9.5	7.50	47.1	YES	
20	0.92	195	179.4	10.0	7.60	47.2	YES	
21	0.83	195	161.9	10.5	7.50	43.6	YES	
22	0.88	195	171.6	10.5	7.60	45.4	YES	
23	0.85	195	165.8	10.5	7.60	45.3	YES	
24	0.82	195	159.9	10.0	7.60	46.7	YES	
25	0.75	195	146.3	10.0	7.70	48.0	YES	
26	0.72	195	140.4	10.0	7.70	47.8	YES	
27	0.75	195	146.3	10.5	7.60	44.8	YES	
28	0.79	195	154.1	10.0	7.70	48.2	YES	
29	0.69	195	134.6	10.0	7.80	49.4	YES	
30	0.83	195	161.9	10.0	7.50	45.1	YES	
31	0.83	195	161.9	10.0	7.60	46.7	YES	

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350