

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Marion								
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems								
System Name: Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: MARCH 2025								
	DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	Noon [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
	1			0.17				0.18
	2				0.17			0.19
	3			PLANT				OFF
	4			0.17				0.20
	5			0.22				0.23
	6			0.18				0.22
	7			0.21				0.23
	8				PLANT			OFF
	9				0.20			0.22
	10			PLANT				OFF
	11			0.18				0.19
	12			0.19				0.20
	13			0.19				0.21
	14			0.14				0.16
	15				PLANT			OFF
	16				0.12			0.14
	17			0.13				0.14
	18			PLANT				OFF
	19			0.11				0.14
	20			0.14				0.15
	21			0.17				0.17
	22				0.16			0.17
	23				0.15			0.17
	24			0.16				0.17
	25			0.16				0.17
	26			0.19				0.19
	27			0.20				0.20
	28			0.23				0.24
	29				0.23			0.25
	30				PLANT			OFF
	31			PLANT				OFF
Slow Sand Filter				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 1 NTU? ² YES All daily turbidity readings ≤ 5 NTU? YES				CT's met everyday? YES		All CL2 residuals at entry point ≤ 0.2 mg/l? YES		
Notes: Turbidity from the filters				Printed Name: Michael D. Bradley				
				Signature: Michael D. Bradley			Date: 03-31-2025	
				Phone #: (503) 769 6907			Cert #: 6619	
¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only. Page 1 of 2								

OHA - Drinking Water Program - Surface Water Quality Data Form								
Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: MARCH 2025								
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[C°]		Use tables	Yes / No	[GPM]
1/ 0815 HRS	1.37	75	103	12.5	7.28	34	YES	2,100
2/ 1115 HRS	1.12	75	107	14.2	7.33	7.31	YES	2,100
3/ 8:00 A.M.			PLANT				OFF	
4/ 8:00 A.M.	1.35	75	101	12.2	7.30	36	YES	2,100
5/ 8:00 A.M.	1.34	75	101	12.4	7.35	38	YES	2,100
6/ 8:00 A.M.	1.42	75	107	11.5	7.31	36	YES	2,100
7/ 8:00 A.M.	1.39	75	104	12.4	7.31	36	YES	2,100
8/ 1050 HRS			PLANT				OFF	
9/ 1050 HRS	1.29	75	97	13.5	7.32	31	YES	2,100
10/ 8:00 A.M.			PLANT				OFF	
11/ 8:00 A.M.	1.27	75	95	13.8	7.35	32	YES	2,100
12/ 8:00 A.M.	1.33	75	100	14.2	7.30	31	YES	2,100
13/ 8:00 A.M.	1.33	75	100	13.3	7.33	34	YES	2,100
14/ 8:00 A.M.	1.37	75	103	11.7	7.31	36	YES	2,100
15/ 1125 HRS			PLANT				OFF	
16/ 1125 HRS	1.26	75	95	11.2	7.37	41	YES	2,100
17/ 8:00 A.M.	1.30	75	98	10.6	7.34	39	YES	2,100
18/ 8:00 A.M.			PLANT				OFF	
19/ 8:00 A.M.	1.23	42	52	12.5	7.28	34	YES	3,800
20/ 8:00 A.M.	1.38	75	104	11.6	7.33	36	YES	2,100
21/ 8:00 A.M.	1.38	42	58	11.3	7.35	41	YES	3,800
22/ 1150 HRS	1.44	75	108	12.0	7.20	35	YES	2,100
23/ 1150 HRS	1.30	75	98	14.4	7.31	31	YES	2,100
24/ 0845 HRS	1.29	75	97	14.0	7.25	31	YES	2,100
25/ 0840 HRS	1.31	75	98	14.3	7.22	30	YES	2,100
26/ 0850 HRS	1.33	75	100	13.8	7.23	30	YES	2,100
27/ 0845 HRS	1.32	75	99	15.4	7.22	27	YES	2,100
28/ 0855 HRS	1.31	75	98	15.5	7.23	26	YES	2,100
29/ 1100 HRS	1.34	75	101	15.4	7.26	28	YRS	2,100
30/ 1030 HRS			PLANT				OFF	
31/ 8:00 A.M.			PLANT				OFF	

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, notify DWP by end of next business day.

Page 2 of 2