

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Marion								
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems								
System Name: Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: APRIL 2025								
	DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	Noon [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
	1			0.18				0.24
	2			0.16				0.17
	3			0.14				0.15
	4			0.13				0.13
	5				PLANT			OFF
	6				PLANT			OFF
	7			PLANT				OFF
	8			0.17				0.17
	9			0.14				0.14
	10			0.15				0.16
	11			0.16				0.17
	12				PLANT			OFF
	13				PLANT			OFF
	14			PLANT				OFF
	15			PLANT				OFF
	16			0.23				0.26
	17			0.24				0.25
	18			PLANT				OFF
	19			0.23				0.24
	20				0.21			0.24
	21			0.18				0.19
	22			0.17				0.17
	23			0.14				0.15
	24			0.16				0.18
	25			0.19				0.21
	26				PLANT			OFF
	27				PLANT			OFF
	28			PLANT				OFF
	29			0.29				0.35
30			0.25				0.29	
Slow Sand Filter				Monthly Summary (Answer Yes or No)				
95% of daily turbidity readings ≤ 1 NTU? ² YES All daily turbidity readings ≤ 5 NTU? YES				CT's met everyday? YES		All CL2 residuals at entry point ≤ 0.2 mg/l? YES		
Notes: Turbidity from the filters				Printed Name: Michael D. Bradley				
				Signature: Michael D. Bradley			Date: 04-30-2025	
				Phone #: (503) 871-7469			Cert #: 6619	
¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only. Page 1 of 2								

OHA - Drinking Water Program - Surface Water Quality Data Form								
Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: APRIL 2025								
Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[C°]		Use tables	Yes / No	[GPM]
1/ 8:00 A.M.	1.37	75	103	13.9	7.25	31	Yes	2,100
2/ 8:00 A.M.	1.20	75	90	13.7	7.24	30	YES	2,100
3/ 8:00 A.M.	1.28	75	96	13.1	7.21	32	YES	2,100
4/ 8:00 A.M.	1.38	75	104	13.2	7.28	34	YES	2,100
5/ 1055HRS			PLANT				OFF	
6/ 1130 HRS			PLANT				OFF	
7/ 8:00 A.M.			PLANT				OFF	
8/ 8:00 A.M.	1.28	75	104	14.9	7.33	28	YES	2,100
9/ 8:00 A.M.	1.41	42	59	13.4	7.31	34	YES	3,800
10/ 8:00 A.M.	1.41	75	106	14.1	7.28	31	YES	2,100
11/ 8:00 A.M.	1.29	75	97	14.0	7.23	30	YES	2,100
12/ 1135 HRS			PLANT				OFF	
13/ 1125 HRS			PLANT				OFF	
14/ 8:00 A.M.			PLANT				OFF	
15/ 8:00 A.M.			PLANT				OFF	
16/ 8:00 A.M.	1.14	75	86	15.1	7.24	27	YES	2,100
17/ 8:00 A.M.	1.38	75	104	15.6	7.26	27	YES	2,100
18/ 8:00 A.M.			PLANT				OFF	
19/ 8:00 A.M.	1.28	75	96	15.7	7.48	28	YES	2,100
20/ 1145 HRS	1.27	75	95	15.8	7.37	27	YES	2,100
21/ 8:00 A.M.	1.31	75	98	15.7	7.34	27	YES	2,100
22/ 8:00 A.M.	1.32	75	99	14.6	7.31	28	YES	2,100
23/ 8:00 A.M.	1.50	75	113	14.4	7.37	32	YES	2,100
24/ 8:00 A.M.	1.38	75	104	14.7	7.34	28	YES	2,100
25/ 8:00 A.M.	1.36	75	102	15.5	7.37	27	YES	2,100
26/ 1145 HRS			PLANT				OFF	
27/ 1130 HRS			PLANT				OFF	
28/8:00 A.M.			PLANT				OFF	
29/ 8:00 A.M.	1.30	75	98	15.8	7.46	28	YES	2,100
30/ 8:00 A.M.	1.32	75	99	14.9	7.26	28	YES	2,100

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, notify DWP by end of next business day.

Page 2 of 2