

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Marion
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: JUNE 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	Noon [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				0.18			0.21
2			0.19				0.19
3			0.16				0.20
4			0.17				0.17
5			0.24				0.30
6			0.20				0.25
7				PLANT			OFF
8				0.19			0.20
9			0.18				0.20
10			0.17				0.20
11			0.19				0.20
12			0.18				0.19
13			0.16				0.18
14				PLANT			OFF
15				0.15			0.17
16			0.15				0.16
17			0.15				0.17
18			0.16				0.17
19			0.15				0.16
20			0.16				0.16
21				0.14			0.16
22				PLANT			OFF
23			PLANT				OFF
24			0.14				0.15
25			0.20				0.21
26			0.17				0.20
27			0.17				0.19
28				0.16			0.18
29				0.16			0.17
30			0.17				0.17

Slow Sand Filter

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? ² YES
All daily turbidity readings ≤ 5 NTU? YES

CT's met everyday?
YES

All CL2 residuals at entry point ≤ 0.2 mg/l?
YES

Notes: Turbidity from the filters

Printed Name: Michael D. Bradley

Signature: Michael D. Bradley

Date: 7/7/2025

Phone #: (503) 871-7469

Cert #: 6619

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: JUNE 2025

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[C°]		Use tables	Yes / No	[GPM]
1/ 1115 HRS	1.22	75	92	16.8	7.44	26	Yes	2,100
2/08:00 AM	1.41	75	106	15.9	7.50	28	YES	2,100
3/ 08:00 AM	1.22	75	92	17.2	7.44	26	YES	2,100
4/ 8:00 A.M.	1.30	75	98	17.2	7.43	26	YES	2,100
5/ 8:00 A.M.	1.15	42	48	17.7	7.36	24	YES	3,800
6/8:00 A.M.	1.35	75	97	17.6	7.37	24	YES	2,100
7/ 1105 HRS			PLANT				OFF	
8/ 1130 HRS	1.26	75	95	19.8	7.28	21	YES	2,100
9/ 8:00 A.M.	1.37	75	103	18.4	7.42	24	YES	2,100
10/ 8:00 A.M.	1.16	75	87	20.5	7.27	19	YES	2,100
11/ 8:00 A.M.	1.36	75	102	20.6	7.33	19	YES	2,100
12/ 8:00 A.M.	1.36	42	57	19.6	7.37	21	YES	3,800
13/ 8:00 A.M.	1.32	75	99	18.9	7.41	23	YES	2,100
14/ 1155 HRS			PLANT				OFF	
15/ 1210 HRS	0.83	75	62	18.3	7.33	24	YES	2,100
16/ 8:00 A.M.	1.39	75	104	18.8	7.33	23	YES	2,100
17/ 8:00 A.M.	1.36	75	102	18.8	7.38	23	YES	2,100
18/ 8:00 A.M.	1.31	75	98	19.1	7.35	23	YES	2,100
19/ 8:00 A.M.	1.05	75	79	18.7	7.31	22	YES	2,100
20/ 8:00 A.M.	1.25	75	94	18.4	7.37	24	YES	2,100
21/ 1115 HRS	1.42	75	107	18.1	7.40	24	YES	2,100
22/ 1130 HRS			PLANT				OFF	
23/ 8:00 A.M.			PLANT				OFF	
24/ 8:00 A.M.	1.36	75	102	17.6	7.31	24	YES	2,100
25/ 8:00 A.M.	1.37	42	57	19.5	7.39	21	YES	3,800
26/ 8:00 A.M.	1.36	75	102	18.6	7.38	23	YES	2,100
27/ 8:00 A.M.	1.40	75	105	18.8	7.39	23	YES	2,100
28/ 1000 HRS	1.35	75	97	19.1	7.36	23	YES	2,100
29/ 1125 HRS	1.32	75	99	19.9	7.34	21	YES	2,100
30/08:00 HRS	1.26	75	95	20.7	7.33	19	YES	2,100

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, notify DWP by end of next business day.

Page 2 of 2