

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Marion
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: SEPTEMBER 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	Noon [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				0.15			0.16
2			PLANT				OFF
3			0.16				0.17
4			0.14				0.14
5			0.14				0.15
6				0.12			0.15
7				PLANT			OFF
8			0.12				0.14
9			0.12				0.14
10			0.12				0.13
11			0.12				0.12
12			PLANT				OFF
13				0.11			0.12
14				0.11			0.12
15			0.11				0.11
16			0.10				0.11
17			PLANT				OFF
18			0.12				0.12
19			0.14				0.16
20				0.13			0.14
21				0.13			0.16
22			0.13				0.14
23			PLANT				OFF
24			0.13				0.14
25			0.11				0.12
26			0.12				0.14
27			0.13				0.13
28			0.12				0.12
29			PLANT				OFF
30			PLANT				OFF

Slow Sand Filter

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings $\leq$ 1 NTU? ² YES
All daily turbidity readings $\leq$ 5 NTU? YES

CT's met everyday?
YES

All CL2 residuals at entry point $\leq$ 0.2 mg/l?
YES

Notes: Turbidity from the filters

Printed Name: Michael D. Bradley

Signature: Michael D. Bradley

Date: 09-30-2025

Phone #: (503) 871-7469

Cert #: 6619

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: SEPTEMBER 2025

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[C°]		Use tables	Yes / No	[GPM]
1/ 1130 HRS	1.17	75	88	19.1	7.34	22	YES	2,100
2/ 8:00 A.M.			PLANT				OFF	
3/ 8:00 A.M.	0.91	42	38	18.3	7.32	24	YES	3,800
4/ 8:00 A.M.	1.25	75	94	17.9	7.31	24	YES	2,100
5/ 8:00 A.M.	1.31	75	98	17.6	7.33	24	YES	2,100
6/ 1100 HRS	1.30	75	98	19.1	7.37	23	YES	2,100
7/ 1145 HRS			PLANT				OFF	
8/ 8:00 A.M.	1.16	75	87	17.6	7.29	24	YES	2,100
9/ 8:00 A.M.	1.28	75	96	16.9	7.37	26	YES	2,100
10/ 8:00 A.M.	1.45	42	61	16.8	7.37	26	YES	3,800
11/ 8:00 A.M.	1.29	75	97	16.5	7.37	26	YES	2,100
12/ 8:00 A.M.			PLANT				OFF	
13/ 1120 HRS	1.03	75	77	18.0	7.36	24	YES	2,100
14/ 1115HRS	1.21	75	91	17.3	7.32	25	YES	2,100
15/ 8:00 A.M.	1.27	75	95	17.6	7.33	24	YES	2,100
16/ 8:00 A.M.	1.24	75	93	17.9	7.39	24	YES	2,100
17/ 8:00 A.M.			PLANT				OFF	
18/ 8:00 A.M.	1.22	75	92	17.7	7.26	24	YES	2,100
19/ 8:00 A.M.	1.28	75	94	17.6	7.31	24	YES	2,100
20/ 1125 HRS	1.29	75	97	18.1	7.36	24	YES	2,100
21/ 1150 HRS	1.20	75	90	18.1	7.36	24	YES	2,100
22/ 8:00 A.M.	1.24	75	93	17.5	7.35	24	YES	2,100
23/ 8:00 A.m.			PLANT				OFF	
24/ 8:00 A.M.	1.09	75	82	17.5	7.28	24	YES	2,100
25/ 8:00 A.M.	1.40	75	105	17.6	7.26	24	YES	2,100
26/ 8:00 A.M.	1.34	42	56	17.2	7.31	25	YES	3,800
27/ 8:00 A.M.	1.38	42	58	17.1	7.31	25	YES	3,800
28/ 8:00 A.M.	1.38	75	104	17.2	7.33	25	YES	2,100
29/ 8:00 A.M.			PLANT				OFF	
30/ 8:00 A.M.			PLANT				OFF	

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, notify DWP by end of next business day.

Page 2 of 2