

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Marion**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **Stayton Water Supply** ID #: **OR4100843** WTP-: **WTP-A** Month/Year: **DECEMBER2025**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	Noon [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1			PLANT				OFF
2			0.12				0.14
3			0.13				0.16
4			0.15				0.16
5			PLANT				OFF
6				0.12			0.14
7				0.11			0.14
8			0.12				0.14
9			0.15				0.16
10			PLANT				OFF
11			PLANT				OFF
12			0.16				0.17
13				0.15			0.17
14				0.14			0.14
15			0.12				0.13
16			0.11				0.13
17			0.12				0.12
18			0.19				0.20
19			0.14				0.14
20				PLANT			OFF
21				PLANT			OFF
22			PLANT				OFF
23			0.29				0.36
24				0.19			0.30
25				0.19			0.20
26			0.17				0.19
27				0.17			0.19
28				0.17			0.19
29			0.18				0.19
30			0.17				0.18
31				0.17			0.18

<b>Slow Sand Filter</b>			<b>Monthly Summary (Answer Yes or No)</b>				
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	YES	CT's met everyday? YES	All CL2 residuals at entry point ≤ 0.2 mg/l? YES				
All daily turbidity readings ≤ 5 NTU?	YES						

<b>Notes:</b> Turbidity from the filters	<b>Printed Name:</b> Michael D. Bradley		
	<b>Signature:</b> Michael D. Bradley		<b>Date:</b> 01-05-2026
	<b>Phone #:</b> (503) 769 6907		<b>Cert #:</b> 6619

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**Stayton Water Supply ID #: OR4100843 WTP:- WTP-A Month/Year: DECEMBER 2025**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[C°]		Use tables	Yes / No	[GPM]
1/ 8:00 A.M.			PLANT					OFF
2/ 8:00 A.M.	1.22	75	92	12.2	7.28	36	YES	2,100
3/ 8:00 A.M.	1.29	75	97	11.7	7.31	36	YES	2,100
4/ 8:00 A.M.	1.27	75	95	12.5	7.34	34	YES	2,100
5/ 8:00 A.M.			PLANT				OFF	
6/ 1110 HRS	1.10	75	83	11.8	7.30	36	YES	2,100
7/ 1040 HRS	1.30	75	98	13.0	7.25	34	YES	2,100
8/ 8:00 A.M.	1.38	75	104	13.1	7.23	32	YES	2,100
9/ 8:00 A.M.	1.31	42	55	14.5	7.29	28	YES	3,800
10/ 8:00 A.M.			PLANT				OFF	
11/ 8:00 A.m.			PLANT				OFF	
12/ 8:00 A.M.	1.12	75	84	13.6	7.29	31	YES	2,100
13/ 1100 HRS	1.31	75	98	14.3	7.32	31	YES	2,100
14/ 1115 HRS	1.29	75	97	14.2	7.30	31	YES	2,100
15/ 8:00 A.M.	1.23	75	92	14.3	7.27	31	YES	2,100
16/ 8:00 A.M.	1.31	75	98	14.1	7.26	31	YES	2,100
17/ 8:00 A.M.	1.27	75	95	13.3	7.27	34	YES	2,100
18/ 8:00 A.M.	1.48	42	62	13.6	7.31	31	YES	3,800
19/ 8:00 A.M.	1.47	75	110	13.8	7.29	31	YES	2,100
20/ 1115 HRS			PLANT				OFF	
21/ 1100 HRS			PLANT				OFF	
22/ 8:00 A.M.			PLANT				OFF	
23/ 8:00 A.M.>	1.31	75	98	13.4	7.33	34	YES	2,100
24/ 1130 HRS	1.29	75	97	11.9	7.36	38	YES	2,100
25/ 1100 HRS	1.29	75	97	11.5	7.30	36	YES	2,100
26/ 0920 HRS	0.82	75	62	12.0	7.30	36	YES	2,100
27/ 1100 HRS	1.42	75	107	12.7	7.25	34	YES	2,100
28/ 1200 HRS	1.38	75	104	10.6	7.31	39	YES	2,100
29/08:00 A.M.	1.36	75	102	11.2	7.15	38	YES	2,100
30/ 8:00 A.M.	1.33	75	100	11.1	7.29	39	YES	2,100
31/ 0915	1.39	75	104	9.8	7.32	42	YES	2,100

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L or CT not met, notify DWP by end of next business day.