

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Marion**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: **Stayton Water Supply** ID #: **OR4100843** WTP-: **WTP-A** Month/Year: **FEBRUARY 2026**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	Noon [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1				PLANT			OFF
2			PLANT				OFF
3			0.15				0.16
4			0.18				0.20
5			0.16				0.21
6			0.25				0.25
7				PLANT			OFF
8				PLANT			OFF
9			PLANT				OFF
10			0.25				0.27
11			0.34				0.41
12			0.32				0.34
13			0.33				0.34
14				PLANT			OFF
15				0.18			0.20
16				0.15			0.15
17			0.20				0.21
18			PLANT				OFF
19			0.14				0.15
20			0.09				0.14
21				0.10			0.10
22				0.10			0.12
23			0.09				0.10
24			0.09				0.09
25			PLANT				OFF
26			0.09				0.10
27			0.15				0.16
28			PLANT				OFF
29							
30							

<b>Slow Sand Filter</b>			<b>Monthly Summary (Answer Yes or No)</b>		
95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup>	YES	CT's met everyday? YES	All CL2 residuals at entry point ≤ 0.2 mg/l? YES		
All daily turbidity readings ≤ 5 NTU?	YES				

<b>Notes:</b> Turbidity from the filters	<b>Printed Name:</b> Michael D. Bradley	
	<b>Signature:</b> Michael D. Bradley	<b>Date:</b> 03-02-2026
	<b>Phone #:</b> (503) 871-7469	<b>Cert #:</b> 6619

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: FEBRUARY 2026**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>a</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>a</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[C°]		Use tables	Yes / No	[GPM]
1/ 1130 HRS			PLANT				OFF	
2/ 8:00 A.M.			PLANT				OFF	
3/ 8:00 A.M.	1.38	75	104	11.1	7.28	39	YES	2,100
4/ 8:00 A.M.	1.39	75	104	10.5	7.29	39	YES	2,100
5/ 8:00 A.M.	1.29	75	97	10.4	7.33	42	YES	2,100
6/ 8:00 A.M.	1.37	75	103	11.0	7.33	39	YES	2,100
7/ 1140 HRS			PLANT				OFF	
8/ 1130 HRS			PLANT				OFF	
9/ 8:00 A,M,			PLANT				OFF	
10/ 8:00 A.M.	1.16	75	87	11.0	7.34	39	YES	2,100
11/ 8:00 A.M.	1.33	75	100	11.7	7.34	36	YES	2,100
12/ 8:00 A.M.	1.14	75	86	11.2	7.37	41	YES	2,100
13/ 8:00 A.M.	1.22	75	92	10.3	7.37	43	YES	2,100
14/ 1115 HRS			PLANT				OFF	
15/ 1125 HRS	1.09	75	82	11.9	7.34	36	YES	2,100
16/ 1040 HRS	1.24	75	93	12.2	7.32	36	YES	2,100
17/ 8:00 A.M.	1.30	75	98	12.3	7.34	36	YES	2,100
18/ 8:00 A.M.			PLANT				OFF	
19/ 8:00 A.M.	1.17	75	88	10.9	7.30	39	YES	2,100
20/ 8:00 A.M.	1.22	75	92	10.1	7.25	42	YES	2,100
21/ 1140 HRS	1.29	75	97	12.0	7.33	36	YES	2,100
22/ 1200 HRS	1.21	75	91	13.1	7.29	34	YES	2,100
23/ 8:00 A.M.	1.25	75	94	12.6	7.24	32	YES	2,100
24/ 8:00 A.M.	1.33	75	100	11.8	7.27	36	YES	2,100
25/ 8:00 A.M.			PLANT				OFF	
26/ 8:00 A.M.	1.21	75	91	10.1	7.29	42	YES	2,100
27/ 8:00 A.M.	1.26	75	95	12.0	7.36	38	YES	2,100
28/ 8:00 A.M.			PLANT				OFF	
29/								
30/								

<sup>a</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/L or CT not met, notify DWP by end of next business day.