

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Marion
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: **Stayton Water Supply** ID #: **OR4100843** WTP-: **WTP-A** Month/Year: **MARCH 2026**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	Noon [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1				PLANT			OFF
2			PLANT				OFF
3			0.17				0.18
4			0.15				0.15
5			0.14				0.15
6			0.12				0.14
7				0.13			0.14
8				0.13			0.14
9			0.13				0.13
10			0.16				0.16
11			0.15				0.16
12			0.12				0.14
13			0.10				0.11
14				0.10			0.11
15				0.09			0.11
16			PLANT				OFF
17			0.07				0.14
18			PLANT				OFF
19			0.19				0.19
20			0.14				0.16
21				PLANT			OFF
22				PLANT			OFF
23			PLANT				OFF
24			PLANT				OFF
25			0.16				0.16
26			0.16				0.16
27			0.17				0.18
28				PLANT			OFF
29				PLANT			OFF
30			PLANT				OFF
31			0.19				0.20

Slow Sand Filter		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	YES	CT's met everyday?	All CL2 residuals at entry point ≤ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	YES	YES	YES
Notes: Turbidity from the filters	Printed Name: Michael D. Bradley		
	Signature: Michael D. Bradley		Date: 03-31-2026
	Phone #: (503) 769 6907		Cert #: 6619

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

Stayton Water Supply ID #: OR4100843 WTP-: WTP-A Month/Year: MARCH 2026

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[C°]		Use tables	Yes / No	[GPM]
1/ 1125 HRS			PLANT				OFF	
2/ 8:00 A.M.			PLANT				OFF	
3/ 8:00 A.M.	1.14	75	86	11.7	7.40	38	YES	2,100
4/ 8:00 A.M.	1.23	75	92	13.2	7.37	35	YES	2,100
5/ 8:00 A.M.	1.36	75	102	13.6	7.39	32	YES	2,100
6/ 8:00 A.M.	1.18	75	89	14.0	7.32	32	YES	2,100
7/ 1125 HRS	1.29	75	97	13.3	7.33	34	YES	2,100
8/ 1125 HRS	1.28	75	96	13.6	7.33	31	YES	2,100
9/ 8:00 A.M.	1.25	75	94	13.7	7.33	31	YES	2,100
10/ 8:00 A.M.	1.29	75	97	12.3	7.34	36	YES	2,100
11/ 8:00 A.M.	1.29	75	97	12.6	7.38	35	YES	2,100
12/ 8:00 A.M.	1.29	75	97	13.6	7.32	31	YES	2,100
13/ 8:00 A.M.	1.29	75	97	13.7	7.34	31	YES	2,100
14/ 1140 HRS	1.31	75	98	11.7	7.32	36	YES	2,100
15/ 1115 HRS	1.38	75	104	12.3	7.37	38	YES	2,100
16/ 8:00 A.M.			PLANT				OFF	
17/ 8:00 A.M.	1.26	75	95	13.5	7.24	32	YES	2,100
18/ 8:00 A.M.			PLANT				OFF	
19/ 8:00 A.M.	1.20	42	50	13.7	7.38	32	YES	3,800
20/ 8:00 A.M.	1.33	75	100	13.7	7.34	31	YES	2,100
21/ 1120 HRS			PLANT				OFF	
22/ 1100 HRS			PLANT				OFF	
23/ 8:00 A.M.			PLANT				OFF	
24/ 8:00 A.M.			PLANT				OFF	
25/ 8:00 A.M.	1.45	75	109	13.7	7.35	32	YES	2,100
26/ 8:00 A.M.	1.40	75	105	13.1	7.37	35	YES	2,100
27/ 8:00 A.M.	1.29	75	97	13.1	7.39	35	YES	2,100
28/ 1040 HRS			PLANT				OFF	
29/ 1135 HRS			PLANT				OFF	
30/ 8:00 A.M.			PLANT				OFF	
31/ 8:00 A.M.	1.36	42	57	13.8	7.41	32	YES	3,800

³ If Cl₂ at entry point < 0.2 mg/L or CT not met, notify DWP by end of next business day.