


OHA - Drinking Water Services - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Baker
 Month/Year: Jun-24

System Name: City of Sumpter ID#: 41 00815 WTP : TP -

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.43				0.43
2			0.43				0.43
3			0.42				0.42
4			0.41				0.41
5			0.40				0.40
6			0.40				0.40
7			0.40				0.40
8			0.39				0.39
9			0.39				0.39
10			0.39				0.39
11			0.39				0.39
12			0.39				0.39
13			0.39				0.39
14			0.39				0.39
15			0.36				0.36
16			0.39				0.39
17			0.39				0.39
18			0.39				0.39
19			0.39				0.39
20			0.39				0.39
21			0.27				0.27
22			0.46				0.46
23			0.61				0.61
24			0.45				0.45
25			0.70				0.70
26			0.45				0.45
27			0.74				0.74
28			0.79				0.79
29			0.81				0.81
30			0.82				0.82
31							

Slow Sand/Membrane/DE Filtration/Unfiltered			
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes
Notes:	PRINTED NAME: Levi Tickner		
	SIGNATURE: 		DATE 7/10/2024
	PHONE #: (541)760-9362		CERT #: T-008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

All daily turbidity read

