


OHA - Drinking Water Services - Surface Water Quality Data Form
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Baker**
 Month/Year: **Mar-26**

System Name: City of Sumpter **ID#: 41 00845** **WTP : TP -**

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			0.05				0.05
2			0.05				0.05
3			0.05				0.05
4			0.05				0.05
5			0.05				0.05
6			0.05				0.05
7			0.05				0.05
8			0.05				0.05
9			0.05				0.05
10			0.06				0.06
11			0.06				0.06
12			0.06				0.06
13			0.06				0.06
14			0.05				0.05
15			0.06				0.06
16			0.05				0.05
17			0.05				0.05
18			0.05				0.05
19			0.05				0.05
20			0.05				0.05
21			0.05				0.05
22			0.05				0.05
23			0.06				0.06
24			0.06				0.06
25			0.06				0.06
26			0.06				0.06
27			0.06				0.06
28			0.06				0.06
29			0.06				0.06
30			0.06				0.06
31			0.06				0.06

Slow Sand/Membrane/DE Filtration/Unfiltered			
95% of daily turbidity readings ≤ 1 NTU? ²	Yes	CT's met everyday? (see back)	
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes:	PRINTED NAME: Levi Tickner	
	SIGNATURE: 	4/10/2026
	PHONE #: (541)760-9362	CERT #: T-008780

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name:	City of Sumpter	ID#: 41	00845	Month/Year: Mar-26	Disinfection Giardia Log	Inactiv:	1.0
---------------------	-----------------	----------------	-------	---------------------------	---------------------------------	-----------------	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	150	120.0	3.1	8.13	90.3	YES	389
2	1.09	150	163.5	3.1	8.14	93.8	YES	389
3	0.84	150	126.0	3.5	8.14	88.6	YES	389
4	0.73	150	109.5	3.6	8.15	87.1	YES	389
5	0.99	150	148.5	3.8	8.14	88.3	YES	389
6	0.79	150	118.5	3.2	8.14	89.9	YES	389
7	0.65	150	97.5	3.5	8.14	86.6	YES	389
8	0.87	150	130.5	3.9	8.15	86.8	YES	389
9	0.71	150	106.5	3.9	8.15	85.1	YES	389
10	0.59	150	88.5	3.6	8.14	85.4	YES	389
11	0.59	150	88.5	3.8	8.14	84.2	YES	389
12	0.59	150	88.5	3.7	8.14	84.8	YES	389
13	0.59	150	88.5	3.9	8.15	83.9	YES	389
14	0.87	150	130.5	3.7	8.17	88.6	YES	389
15	0.8	150	120.0	3.7	8.17	87.9	YES	389
16	0.72	150	108.0	4.3	8.17	83.5	YES	389
17	0.99	150	148.5	4.1	8.18	87.8	YES	389
18	0.82	150	123.0	4.4	8.12	82.4	YES	389
19	0.75	150	112.5	5.6	8.20	77.5	YES	389
20	0.99	150	148.5	5.7	8.19	78.8	YES	389
21	0.69	150	103.5	5.8	8.17	75.0	YES	389
22	0.5	150	75.0	6.5	8.15	69.4	YES	389
23	0.62	150	93.0	6.5	8.12	69.6	YES	389
24	0.5	150	75.0	6.1	8.10	70.1	YES	389
25	0.5	150	75.0	6.1	8.09	69.8	YES	389
26	0.83	150	124.5	5.9	8.08	73.3	YES	389
27	0.69	150	103.5	6.2	8.07	70.4	YES	389
28	0.59	150	88.5	6.0	8.06	70.2	YES	389
29	0.71	150	106.5	6.6	8.04	67.9	YES	389
30	0.57	150	85.5	6.5	8.03	67.0	YES	389
31	0.56	150	84.0	6.2	8.04	68.5	YES	389

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350