

## OHA - Drinking Water Program - Turbidity Monitoring Report Form

Conventional or Direct Filtration

County: Douglas

System Name: Sutherlin, City of ID# OR4100847					WTP: WTP-A	MONTH/YEAR August, 2022	
Nonparallel							
Day	12 AM NTU	4 AM NTU	8 AM NTU	Noon NTU	4 PM NTU	8 PM NTU	<sup>1</sup> Highest Reading of the Day NTU
1	0.03	0.03	0.03	OFF	0.03	0.03	0.11
2	0.04	0.03	0.03	0.03	0.03	0.03	0.05
3	0.03	0.03	0.03	OFF	0.03	0.03	0.25
4	0.03	0.03	0.03	0.03	0.03	0.03	0.07
5	0.03	0.03	0.03	0.03	0.03	0.03	0.06
6	0.03	0.03	0.03	0.03	0.03	0.06	0.08
7	0.07	0.05	0.04	0.04	OFF	OFF	0.10
8	0.04	0.03	0.04	OFF	0.04	0.03	0.09
9	0.06	0.03	0.03	0.04	0.04	0.04	0.10
10	0.04	0.03	0.03	0.03	0.04	0.03	0.07
11	0.04	0.04	OFF	0.04	0.02	0.04	0.11
12	0.03	0.03	0.04	0.04	0.04	0.04	0.05
13	0.04	0.04	0.04	0.04	0.04	0.05	0.06
14	0.04	0.04	0.04	0.04	0.04	0.03	0.07
15	0.07	0.03	0.03	0.04	0.04	0.05	0.07
16	0.04	0.04	0.04	0.04	0.04	0.05	0.07
17	0.05	0.05	0.05	0.06	0.05	0.05	0.09
18	0.05	0.05	0.05	0.05	0.07	0.05	0.07
19	0.05	0.05	0.05	0.06	0.05	0.05	0.09
20	0.05	0.06	0.05	0.05	0.06	0.05	0.07
21	0.05	0.06	0.06	0.06	0.06	0.05	0.07
22	0.05	0.06	0.06	0.05	0.05	0.05	0.08
23	0.05	0.04	0.05	0.05	0.06	0.05	0.07
24	0.05	0.06	0.06	0.05	0.05	0.05	0.09
25	0.05	0.05	0.05	0.05	0.05	0.05	0.06
26	0.05	0.05	0.05	0.06	0.04	0.04	0.07
27	0.04	0.05	0.05	0.05	0.05	0.05	0.06
28	0.05	0.05	0.05	0.05	0.05	0.05	0.10
29	0.05	0.05	0.05	0.05	0.04	0.04	0.07
30	0.04	0.04	0.05	0.05	0.05	0.04	0.08
31	0.05	0.05	0.05	0.04	0.04	0.04	0.06
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of the 4-hour turbidity reading ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				CT's met everyday? <i>(see back)</i>		All Cl <sub>2</sub> residual at entry point ≥ 0.2mg/l? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <sup>2</sup>							
Notes:				Printed Name: <i>John Bachman</i> Signature: <i>[Signature]</i> Date: <i>9/6/22</i> Phone #: ( <i>541</i> ) 459 5768 Cert #: <i>6900</i>			

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE = Individual Filter Effluent. (OAR 333-061-0040(1)(e)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

Sutherlin, City of		ID# OR4100847		WTP: WTP-A MONTH/YEAR August, 2022				Required Log Inactivation: 1.0	
Nonparallel									
Date/ Time	Minimum CL <sub>2</sub> Residual at 1st user (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp.	pH	Required CT	CT Met <sup>3</sup>	Peak Hourly Demand Flow	
	PPM or MG/L	Minutes	C x T	°C		Use Tables	Y/N	[GPM]	
1/ 9:30	1.7	50.9	86.53	22	6.64	20	YES	1260	
2/ 9:10	1.3	50.9	66.17	22	6.71	19	YES	1260	
3/ 8:30	1.5	50.9	76.35	22	6.71	20	YES	1260	
4/ 8:50	1.5	50.9	76.35	21	6.35	17	YES	1260	
5/ 9:00	1.6	50.9	81.44	20	6.71	20	YES	1260	
6/ 9:45	1.5	50.9	76.35	20	6.48	17	YES	1260	
7/ 9:55	1.5	50.9	76.35	20	6.36	17	YES	1260	
8/ 9:30	1.5	50.9	76.35	21	6.40	17	YES	1260	
9/ 9:00	1.4	50.9	71.26	21	6.63	19	YES	1260	
10/ 9:30	1.5	50.9	76.35	21	6.59	20	YES	1260	
11/ 7:00	1.4	50.9	71.26	21	6.45	16	YES	1260	
12/ 8:45	1.5	50.9	76.35	20	6.75	20	YES	1260	
13/ 9:45	1.6	50.9	81.44	19	6.69	26	YES	1260	
14/ 10:35	1.6	50.9	81.44	19	6.62	26	YES	1260	
15/ 9:45	1.6	50.9	81.44	20	6.70	20	YES	1260	
16/ 8:55	1.6	50.9	81.44	21	6.99	20	YES	1260	
17/ 9:00	1.4	50.9	71.26	21	6.74	19	YES	1260	
18/ 8:30	1.4	50.9	71.26	22	6.75	19	YES	1260	
19/ 9:00	1.5	50.9	76.35	22	6.73	20	YES	1260	
20/ 9:30	1.4	50.9	71.26	22	6.72	19	YES	1260	
21/ 9:25	1.6	50.9	81.44	21	6.67	20	YES	1260	
22/ 8:30	1.6	50.9	81.44	22	7.16	24	YES	1260	
23/ 9:00	1.6	50.9	81.44	22	6.75	20	YES	1260	
24/ 8:30	1.6	50.9	81.44	22	6.71	20	YES	1260	
25/ 8:00	1.7	50.9	86.53	22	6.65	20	YES	1260	
26/ 8:20	1.4	50.9	71.26	22	6.65	19	YES	1260	
27/ 9:15	1.6	50.9	81.44	22	6.64	20	YES	1260	
28/ 10:50	1.6	50.9	81.44	20	6.68	20	YES	1260	
29/ 8:30	1.6	50.9	81.44	20	6.78	20	YES	1260	
30/ 8:30	1.6	50.9	81.44	20	6.60	20	YES	1260	
31/ 8:30	1.4	50.9	71.26	22	6.69	19	YES	1260	

<sup>3</sup>If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.