

OHA - Drinking Water Program - Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Douglas

System Name: Sutherlin, City of ID# OR4100847								WTP: WTP-A February, 2026	
Nonpariel									
Day	12 AM NTU	4 AM NTU	8 AM NTU	Noon NTU	4 PM NTU	8 PM NTU	Highest Reading of the Day NTU		
1	0.027	OFF	OFF	0.026	0.024	0.024	0.032		
2	OFF	OFF	0.025	0.026	OFF	OFF	0.044		
3	0.026	OFF	OFF	0.025	0.026	OFF	0.080		
4	OFF	OFF	0.027	0.026	OFF	OFF	0.053		
5	0.024	OFF	OFF	0.025	0.025	0.025	0.031		
6	OFF	OFF	0.025	0.025	OFF	OFF	0.030		
7	0.024	0.026	OFF	0.027	0.025	0.025	0.032		
8	OFF	OFF	0.024	0.031	0.061	0.068	0.114		
9	OFF	OFF	OFF	0.042	0.038	OFF	0.100		
10	OFF	0.053	0.059	0.052	OFF	0.038	0.101		
11	0.045	OFF	OFF	0.040	0.045	OFF	0.101		
12	0.046	0.052	OFF	OFF	0.040	OFF	0.101		
13	OFF	0.035	OFF	0.039	0.038	OFF	0.055		
14	OFF	0.038	OFF	0.032	0.055	OFF	0.156		
15	OFF	0.030	0.031	0.033	0.033	OFF	0.060		
16	OFF	0.035	OFF	0.040	0.032	OFF	0.042		
17	0.031	OFF	OFF	0.040	OFF	OFF	0.082		
18	0.037	OFF	OFF	0.093	0.045	OFF	0.093		
19	OFF	OFF	0.060	0.035	0.041	OFF	0.127		
20	OFF	0.033	0.090	0.055	OFF	0.071	0.135		
21	0.045	0.032	OFF	0.041	0.093	0.035	0.193		
22	OFF	OFF	OFF	0.033	0.070	0.031	0.097		
23	OFF	OFF	OFF	0.079	0.043	OFF	0.079		
24	OFF	OFF	OFF	OFF	0.054	0.057	0.226		
25	0.063	OFF	OFF	OFF	0.043	0.049	0.243		
26	OFF	OFF	OFF	0.039	0.052	OFF	0.116		
27	OFF	0.046	0.053	OFF	0.069	0.033	0.097		
28	0.044	OFF	OFF	0.038	0.037	0.036	0.063		
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)					
95% of the 4-hour turbidity reading \leq 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No				CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No		All Cl ₂ residual at entry point \geq 0.2mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No			
All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No									
All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes <input type="radio"/> No									
Notes:				Printed Name: Alan Taylor					
				Signature: Alan Taylor			Date: 3/3/26		
				Phone #: (541) 459-5768			Cert #: 08797		

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individual Filter Effluent. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Sutherlin, City of		ID# OR4100847		WTP: WTP-A MONTH/YEAR: February, 2026			Required Log Inactivation: 1.0	
Nonpariel								
Date/ Time	Minimum CL ₂ Residual at 1st user (C) ³	Contact Time (T)	Actual CT	Temp.	pH	Required CT	CT Met ³	Peak Hourly Demand Flow
	PPM or MG/L	Minutes	C x T	° C		Use Tables	Y/N	[GPM]
1/ 12:00	1.5	50.9	76.35	11	7.25	48	YES	1400
2/ 10:00	1.5	50.9	76.35	11	7.41	48	YES	1400
3/ 10:30	1.5	50.9	76.35	10	7.27	48	YES	1400
4/ 8:35	1.5	50.9	76.35	8	7.16	64	YES	1400
5/ 11:00	1.5	50.9	76.35	8	7.17	64	YES	1400
6/ 11:25	1.5	50.9	76.35	8	7.30	64	YES	1400
7/ 12:00	1.5	50.9	71.26	11	7.20	48	YES	1400
8/ 11:00	1.5	50.9	76.35	11	7.28	48	YES	1400
9/ 11:30	1.5	50.9	76.35	12	7.09	48	YES	1400
10/ 8:45	1.5	50.9	76.35	10	7.17	48	YES	1400
11/ 11:45	1.7	50.9	86.53	10	7.19	49	YES	1400
12/ 13:00	1.6	50.9	81.44	10	7.19	48	YES	1400
13/ 11:55	1.5	50.9	76.35	10	7.17	48	YES	1400
14/ 1:30	1.6	50.9	81.44	10	7.15	48	YES	1400
15/ 8:44	1.6	50.9	81.44	11	7.22	48	YES	1400
16/ 12:31	1.7	50.9	86.53	12	7.23	49	YES	1400
17/ 11:10	1.6	50.9	81.44	11	6.77	40	YES	1400
18/ 10:45	1.5	50.9	76.35	9	7.08	64	YES	1400
19/ 11:40	1.6	50.9	81.44	10	7.20	48	YES	1400
20/ 11:10	1.6	50.9	81.44	10	7.17	48	YES	1400
21/ 12:45	1.5	50.9	76.35	8	7.27	64	YES	1400
22/ 10:30	1.6	50.9	81.44	12	7.19	48	YES	1400
23/ 11:00	1.7	50.9	86.53	13	7.24	49	YES	1400
24/ 11:03	1.6	50.9	81.44	13	6.81	40	YES	1400
25/ 13:40	1.6	50.9	81.44	13	6.93	40	YES	1400
26/ 11:50	1.7	50.9	86.53	11	7.03	49	YES	1400
27/ 7:22	1.7	50.9	86.53	11	7.13	49	YES	1400
28/ 2:00	1.6	50.9	81.44	11	7.09	48	YES	1400

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.