

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Conventional or Direct Filtration

County:

Douglas

Month/Year:

September, 25

System Name: Sutherlin, City of

ID#: 41 00847

WTP : TP-B, Cooper Creek WTP

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	OFF	OFF	OFF	OFF	OFF	OFF	OFF
4	OFF	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	OFF	OFF	0.055	0.047	OFF	OFF	0.197
10	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11	OFF	OFF	0.047	0.043	OFF	OFF	0.072
12	OFF	OFF	0.048	0.050	OFF	OFF	0.062
13	OFF	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	OFF	OFF	OFF	OFF	OFF
16	OFF	OFF	0.053	0.045	OFF	OFF	0.079
17	OFF	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	OFF	OFF	OFF	OFF	OFF
23	OFF	OFF	0.037	0.030	OFF	OFF	0.205
24	OFF	OFF	OFF	OFF	OFF	OFF	OFF
25	OFF	OFF	0.031	0.046	OFF	OFF	0.103
26	OFF	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	OFF	OFF	OFF	OFF	OFF

Conventional or Direct Filtration

95% of 4-hour turbidity readings $\leq$ 0.3 NTU?☒ Yes ☐ NoAll 4-hour turbidity readings $\leq$ 1 NTU?☒ Yes ☐ NoAll turbidity readings < IFE² triggers☒ Yes ☐ No

Monthly Summary (Answer Yes or No)

CT's met everyday?
(see back)☒ Yes ☐ NoAll Cl₂ residual at entry point
 $\geq$ 0.2 mg/l?☒ Yes ☐ No

Notes:

NAME: Alan Taylor

SIGNATURE: Alan Taylor

DATE: 10/2/25

PHONE #: (541) 459-5768

CERT #: 08197

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP: B - Cooper Creek

System Name: Sutherlin, City of

ID#: 41 00847

Month/Year: September, 2011

Disinfection
Giardia Log
Inactiv:

0.500

Day	Time	Residual at 1st User	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3	9:20	1.5	70.00	105	12	6.76	20	YES	1400
4	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
5	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
6	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
7	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9	9:46	1.4	70.00	98	12	6.81	19	YES	1400
10	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
11	9:54	1.7	70.00	119	12	6.93	20	YES	1400
12	10:27	1.4	70.00	98	11	6.77	19	YES	1400
13	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
14	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
15	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
16	12:14	1.6	70.00	112	11	6.78	20	YES	1400
17	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
18	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
19	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
20	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
21	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
22	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
23	11:00	1.5	70.00	105	12	7.05	24	YES	1400
24	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
25	12:50	1.5	70.00	105	12	7.05	24	YES	1400
26	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
27	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
28	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
29	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF
30	OFF	OFF	70.00	OFF	OFF	OFF	OFF	OFF	OFF